



DALLAS/FORT WORTH
INTERNATIONAL AIRPORT

October 23, 2009

ADDENDUM NO. 3

Re: Solicitation for Non-Public Facilities Maintenance Services - Contract 7005221

THIS ADDENDUM IS AN INTEGRAL PART OF THE SOLICITATION AND MUST BE SIGNED AND RETURNED WITH THE PROPOSAL.

Please be advised of the following change or clarification to the above referenced Solicitation.

Change 1. Attachment 1.4 – Mechanical Tasks page 25 of 29, Glycol Water Treatment; delete the word “Glycol” from the title of the task list.

Please also be advised of the following clarifications to the above referenced Solicitation resulting from the questions received October 16, 2009:

1. Attachment 1.4 – Mechanical Tasks pg 25 of 29 – calls out Glycol water treatment – monthly tasks – where / what buildings on this solicitation is the applicable.
 - ANSWER - Reference Change 1 above. The answer given to Question 15 in Addendum 2 was in error when it stated the Reverse Osmosis facility required glycol water treatment by the successful bidder on this contract. The water treatment in this facility is provided by others. However, there is water treatment required at the Fire Stations and the AOC, which contain closed loop chiller systems.

NOTE: A copy of this addendum shall be acknowledged by appropriate signature and attached to the submitted proposal.

Company Name

Signed

Date

If you have any questions regarding this addendum, contact **Miriam Seymour** during normal working hours (8:00 a.m. to 4:30 p.m., Monday through Friday) at mseymour@dfwairport.com or 972-973-5601 (fax).

Sincerely,

A handwritten signature in black ink, appearing to read "Miriam Seymour", written over a horizontal line.

Miriam Seymour
Senior Contract Administrator
Procurement and Materials Management