

**EXHIBIT A**

**DALLAS-FORT WORTH INTERNATIONAL AIRPORT**

**CONSTRUCTION AND FIRE PREVENTION STANDARDS RESOLUTION**

**AND**

**AMENDMENTS TO THE CODES**

**October 2007**

---

**TABLE OF CONTENTS**

PART ONE -- CONSTRUCTION AND FIRE PREVENTION STANDARDS RESOLUTION ..... 1

SECTION 1 TITLE ..... 1

SECTION 2 PURPOSE ..... 1

SECTION 3 CREATION OF BOARD OF APPEALS (BOA)..... 2

SECTION 4 COMPOSITION OF BOA ..... 2

SECTION 5 EX-OFFICIO MEMBERS..... 4

SECTION 6 MEETINGS: QUORUM ..... 4

SECTION 7 BYLAWS AND RECORDS ..... 5

SECTION 8 AUTHORITY AND POWER..... 5

SECTION 9 RIGHT OF APPEAL ..... 6

SECTION 10 AGENDA AND RECORDS..... 6

SECTION 11 HEARING ..... 6

SECTION 12 STAY OF PROCEEDINGS..... 6

SECTION 13 2006 INTERNATIONAL BUILDING CODE ADOPTED..... 7

SECTION 14 2006 INTERNATIONAL FIRE CODE ADOPTED ..... 7

SECTION 15 2005 NATIONAL ELECTRICAL CODE ADOPTED ..... 7

SECTION 16 2006 INTERNATIONAL MECHANICAL CODE ADOPTED ..... 7

SECTION 17 2006 INTERNATIONAL PLUMBING CODE ADOPTED ..... 7

SECTION 18 2006 INTERNATIONAL FUEL GAS CODE ADOPTED ..... 8

SECTION 19 2006 INTERNATIONAL ENERGY CONSERVATION CODE ADOPTED ..... 8

SECTION 20 REQUIRED PERMITS ..... 8

SECTION 21 REQUIRED FEES ..... 9

SECTION 22 LICENSES REQUIRED..... 9

SECTION 23 ENFORCEMENT ..... 9

SECTION 24 SPECIAL ENACTMENT..... 10

SECTION 25 CONFLICTING PROVISIONS..... 10

SECTION 26 SEVERABILITY CLAUSE ..... 10

SECTION 27 PENAL CLAUSE ..... 10

SECTION 28 SAVINGS CLAUSE ..... 11

SECTION 29 PUBLICATION ..... 11

SECTION 30 EFFECTIVE DATE ..... 11

PART TWO – BUILDING CODE AMENDMENTS ..... 1

SECTION 101.1 TITLE ..... 1

SECTION 101.4 REFERENCED CODES..... 1

SECTION 102.6 EXISTING STRUCTURES ..... 1

SECTION 103 DEPARTMENT OF BUILDING SAFETY ..... 2

SECTION 105 PERMITS..... 2

SECTION 105.2 WORK EXEMPT FROM PERMIT ..... 2

SECTION 106.1 SUBMITTAL DOCUMENTS ..... 4

SECTION 106.3.1 APPROVAL OF CONSTRUCTION DOCUMENTS..... 4

SECTION 108 FEES ..... 4

SECTION 110.2 CERTIFICATE ISSUED ..... 6

SECTION 112 BOARD OF APPEALS ..... 6

SECTION 113.4 VIOLATION PENALTIES ..... 6

SECTION 202 DEFINITIONS ..... 7

SECTION 403.1 APPLICABILITY FOR HIGH-RISE BUILDINGS ..... 7

SECTION 412.6 FUELING RAMP DRAINAGE AND AIRCRAFT LOADING WALKWAYS..... 8

SECTION 412.7 FIXED GUIDEWAY TRANSIT SYSTEMS ..... 8

SECTION 903.2 AUTOMATIC SPRINKLER SYSTEMS – WHERE REQUIRED..... 9

SECTION 903.2.7.1 AUTOMATIC SPRINKLER SYSTEMS –GROUP R OCCUPANCIES..... 9

SECTION 903.2.10.3 BUILDINGS 55 FEET OR MORE IN HEIGHT ..... 9

SECTION 903.2.10.4 HIGH-PILED COMBUSTIBLE STORAGE .....	9
SECTION 903.2.10.5 SPRAY BOOTHS AND ROOMS .....	10
SECTION 903.2.10.6 BUILDING AREAS EXCEEDING 6,000 SQUARE FEET .....	10
SECTION 903.2.10.7 SELF-SERVICE STORAGE FACILITY .....	10
SECTION 907.2 FIRE ALARM AND DETECTION SYSTEMS – WHERE REQUIRED.....	10
SECTION 907.2.1.1 FIRE ALARM ACTIVATION – GROUP A OCCUPANCIES.....	11
SECTION 907.2.12 HIGH-RISE BUILDINGS – FIRE ALARM SYSTEM .....	11
SECTION 907.3 MANUAL FIRE ALARM BOXES.....	12
SECTION 907.3.1 MANUAL FIRE ALARM BOXES – LOCATION .....	12
SECTION 907.8.2 HIGH-RISE BUILDINGS – FIRE ALARM ZONES.....	12
SECTION 1003.5 ELEVATION CHANGE.....	12
SECTION 1004.3 POSTING OF OCCUPANT LOAD.....	13
SECTION 1020.1.7 SMOKEPROOF ENCLOSURES.....	13
CHAPTER 11 ACCESSIBILITY .....	13
CHAPTER 29 PLUMBING SYSTEMS .....	14
SECTION 3002.4 ELEVATOR CAR TO ACCOMMODATE AMBULANCE STRETCHER.....	14
CHAPTER 35 REFERENCED STANDARDS .....	14
ADOPTION OF APPENDIX CHAPTER H SIGNS.....	15
SECTION H -101.2 SIGNS EXEMPT FROM PERMITS.....	15
SECTION H105.2 PERMITS, DRAWINGS AND SPECIFICATIONS FOR SIGNS.....	15
PART THREE – FIRE CODE AMENDMENTS .....	1
SECTION 101.1 TITLE .....	1
SECTION 102.6 REFERENCED CODES AND STANDARDS.....	1
SECTION 103.1 DEPARTMENT OF FIRE PREVENTION.....	1
SECTION 105.4.1 CONSTRUCTION DOCUMENTS – SUBMITTALS .....	1
SECTION 105.6.7 COMBUSTIBLE DUST-PRODUCING OPERATIONS.....	2
SECTION 105.6.18 FRUIT AND CROP RIPENING .....	2
SECTION 105.6.30 OPEN BURNING.....	2
SECTION 105.6.33 ORGANIC COATINGS.....	2
SECTION 105.6.37 PYROXYLIN PLASTICS .....	2
SECTION 107.2.2 REINSPECTION AND TESTING .....	3
SECTION 108 BOARD OF APPEALS .....	3
SECTION 109.3 VIOLATION PENALTIES .....	3
SECTION 202 DEFINITIONS .....	3
SECTION 307.4.1 BONFIRES.....	4
SECTION 503.1.1 FIRE APPARATUS ACCESS ROADS – BUILDINGS AND FACILITIES.....	4
SECTION 503.2.1 FIRE APPARATUS ACCESS ROADS – DIMENSIONS .....	4
SECTION 508.5.1 FIRE HYDRANT SYSTEMS – WHERE REQUIRED .....	5
SECTION 704.1 FLOOR OPENINGS AND SHAFTS.....	5
SECTION 903.2 AUTOMATIC SPRINKLER SYSTEMS – WHERE REQUIRED .....	5
SECTION 903.2.7.1 GROUP R .....	5
SECTION 903.2.10.3 BUILDINGS 55 FEET OR MORE IN HEIGHT .....	5
SECTION 903.2.10.4 HIGH-PILED COMBUSTIBLE STORAGE .....	6
SECTION 903.2.10.5 SPRAY BOOTHS AND ROOMS .....	6
SECTION 903.2.10.6 BUILDINGS WITH A FLOOR AREA EXCEEDING 6,000 SQUARE FEET .....	6
SECTION 903.2.14 SELF-SERVICE STORAGE FACILITY .....	7
SECTION 905.2 STANDPIPE SYSTEMS - INSTALLATION STANDARD.....	7
SECTION 907.2 FIRE ALARM AND DETECTION SYSTEMS – WHERE REQUIRED.....	7
SECTION 907.2.1.1 FIRE ALARM ACTIVATION – GROUP A OCCUPANCIES.....	8
SECTION 907.2.12 HIGH-RISE BUILDINGS .....	8
SECTION 907.4 MANUAL FIRE ALARM BOXES .....	8
SECTION 907.4.1 MANUAL FIRE ALARM BOXES – LOCATION .....	9
SECTION 907.9.2 FIRE ALARM ZONES – HIGH-RISE BUILDINGS.....	9
SECTION 1003.5 ELEVATION CHANGE.....	9
SECTION 1004.3 POSTING OF OCCUPANT LOAD.....	10
SECTION 1020.1.7 SMOKEPROOF ENCLOSURES.....	10
SECTION 2705.1.8 HAZARDOUS MATERIALS – FIRE EXTINGUISHING SYSTEMS.....	10
SECTION 3301 EXPLOSIVES AND FIREWORKS – GENERAL .....	10
SECTION 3301.2.4 FINANCIAL RESPONSIBILITY .....	11

SECTION 3406.3.1.3.3 NATURAL GAS PIPELINE SETBACK FROM BUILDINGS .....	11
SECTION 3703.2.5 OUTDOOR STORAGE AND WEATHER PROTECTION .....	11
CHAPTER 45 REFERENCED STANDARDS .....	11
ADOPTION OF APPENDIX CHAPTERS.....	11
PART FOUR – ELECTRICAL CODE AMENDMENTS.....	1
SECTION 101.1 TITLE .....	1
SECTION 301.1 CREATION OF ENFORCEMENT AGENCY .....	1
SECTION 404.2 SCHEDULE OF PERMIT FEES .....	1
SECTION 501.1 SUBMITTAL DOCUMENTS .....	1
SECTION 1003.1 PENALTIES .....	2
CHAPTER 11 MEANS OF APPEAL.....	2
NEC SECTION 230.71(A) MAXIMUM NUMBER OF DISCONNECTS – GENERAL .....	2
NEC SECTION 300.11(A) SECURED IN PLACE.....	2
PART FIVE - MECHANICAL CODE AMENDMENTS .....	1
SECTION 101.1 TITLE .....	1
SECTION 103.1 DEPARTMENT OF MECHANICAL INSPECTION – GENERAL .....	1
SECTION 106.3.1 CONSTRUCTION DOCUMENTS .....	1
SECTION 106.5.2 FEE SCHEDULE .....	1
SECTION 106.5.3 FEE REFUNDS .....	2
SECTION 108.4 VIOLATION PENALTIES .....	2
SECTION 109 MEANS OF APPEAL.....	2
PART SIX - PLUMBING CODE AMENDMENTS .....	1
SECTION 101.1 TITLE .....	1
SECTION 103.1 DEPARTMENT OF PLUMBING INSPECTION – GENERAL .....	1
SECTION 106.3.1 CONSTRUCTION DOCUMENTS .....	1
SECTION 106.6.2 FEE SCHEDULE .....	1
SECTION 106.6.3 FEE REFUNDS .....	2
SECTION 108.4 VIOLATION PENALTIES .....	2
SECTION 109 MEANS OF APPEAL.....	2
SECTION 312.9 INSPECTION AND TESTING OF BACKFLOW PREVENTION ASSEMBLIES .....	2
TABLE 403.1 MINIMUM NUMBER OF PLUMBING FACILITIES .....	2
SECTION 404 ACCESSIBLE PLUMBING FACILITIES .....	3
SECTION 1106.1 CONDUCTORS, LEADERS AND STORM DRAINS.....	3
SECTION 1108 COMBINED SANITARY AND STORM SYSTEM.....	3
PART SEVEN - FUEL GAS CODE AMENDMENTS.....	1
SECTION 101.1 TITLE .....	1
SECTION 103.1 DEPARTMENT OF INSPECTION – GENERAL .....	1
SECTION 106.3.1 CONSTRUCTION DOCUMENTS .....	1
SECTION 106.5.2 FEE SCHEDULE .....	1
SECTION 106.5.3 FEE REFUNDS .....	2
SECTION 108.4 VIOLATION PENALTIES .....	2
SECTION 109 MEANS OF APPEAL.....	2
PART EIGHT - ENERGY CODE AMENDMENTS .....	1

SECTION 101.1 TITLE .....	1
SECTION 101.1.1 DEPARTMENT OF INSPECTION – GENERAL .....	1
SECTION 101.2 SCOPE .....	1
SECTION 101.4.5 MIXED OCCUPANCY .....	1
SECTION 101.5 COMPLIANCE .....	1
SECTION 104.1 CONSTRUCTION DOCUMENTS - GENERAL .....	2
SECTION 108 FEE SCHEDULE .....	2
SECTION 109 FEE REFUNDS .....	2
SECTION 110 VIOLATION PENALTIES .....	2
SECTION 111 MEANS OF APPEAL .....	2
CHAPTER 2 DEFINITIONS .....	3
CHAPTER 4 RESIDENTIAL ENERGY EFFICIENCY .....	3
SECTION 501.3 COMPLIANCE SOFTWARE TOOLS .....	3
SECTION 505.2.1 INTERIOR LIGHTING CONTROLS .....	3
PART NINE – OIL AND GAS EXPLORATION AND PRODUCTION .....	1
SECTION 1 GENERAL INFORMATION .....	1
SECTION 2 DEFINITIONS .....	1
SECTION 3 AIRPORT OVERSIGHT .....	4
SECTION 4 OPERATOR'S AGENT .....	5
SECTION 5 SEISMIC SURVEY PERMIT REQUIREMENTS .....	5
SECTION 6 GAS WELL AND DISPOSAL WELL PERMIT REQUIREMENTS .....	5
SECTION 7 PERMIT APPLICATION .....	7
SECTION 8 PERMITTING PROCEDURE .....	9
SECTION 9 AMENDED GAS WELL PERMITS .....	10
SECTION 10 SUSPENSION OR REVOCATION OF WELL PERMITS .....	11
SECTION 11 PERIODIC REPORTS .....	12
SECTION 12 BOND, LETTERS OF CREDIT, INDEMNITY INSURANCE .....	12
SECTION 13 SETBACK REQUIREMENTS .....	15
SECTION 14 ON SITE AND TECHNICAL REGULATIONS .....	16
SECTION 15 SCREENING .....	27
SECTION 16 CLEANUP AND MAINTENANCE .....	29
SECTION 17 PLUGGED AND ABANDONED WELLS .....	29
SECTION 18 TECHNICAL ADVISOR .....	31
SECTION 19 MEANS OF APPEAL .....	31
SECTION 20 VARIANCE RESOLUTION COMMITTEE .....	31
SECTION 21 SEVERABILITY CLAUSE .....	33

**PART ONE -- CONSTRUCTION AND FIRE PREVENTION STANDARDS  
RESOLUTION**

A Board Resolution creating the Board of Appeals (BOA) of the Dallas-Fort Worth International Airport (the Airport); providing for the selection and term of office of members; providing for public hearings, meetings and procedures therefore; prescribing the authority and powers of the Board of Appeals; providing for appeal from decisions of the Building Official and Fire Chief; providing for a stay of proceedings upon appeal; providing for the adoption of the Building Code; providing for the adoption of the Fire Code; providing for the adoption of the Electrical Code; providing for the adoption of the Mechanical Code; providing for the adoption of the Plumbing Code; providing for the adoption of the Fuel Gas Code; providing for the adoption of the Energy Code; providing for the regulation of oil and gas exploration and production; making it unlawful to perform construction work or oil and gas exploration and production without a permit; making it unlawful to undertake the contracted installation of fire protection, mechanical, plumbing, irrigation or electrical equipment without a proper license to do such work; providing for the termination of the Board of Airport Building Code of Appeals; providing that this resolution shall be cumulative; providing a severability clause; providing a penal clause; providing a savings clause; providing for publication in pamphlet form; providing for publication in a newspaper; and providing an effective date.

**SECTION 1  
TITLE**

This resolution shall be known as the Dallas-Fort Worth International Airport Construction and Fire Prevention Standards Resolution, and referred to herein as (this Resolution).

**SECTION 2  
PURPOSE**

It is the specific intent of the Dallas-Fort Worth International Airport Board (the Airport Board) that standards for construction and fire prevention be used for the health, safety and welfare of all persons at the Airport. The Airport Board finds that construction and fire prevention standards change from time to time and that these standards should stay current with modern practices of construction and fire safety. In carrying out these purposes, it is the intent of the Airport Board that such construction and fire prevention standards be adopted as outlined herein and that a Board of Appeals (BOA) be given limited authority over matters pertaining thereto. The scope of the BOA is as set forth below.

It is the intent of the Airport Board that compliance with the construction and fire prevention standards contained herein is the responsibility of those persons and businesses to which they apply; and that neither the BOA nor the Airport Board, its members, agents and employees, shall be liable or responsible for any errors or omissions arising out of the enforcement or failure to enforce these standards.

### **SECTION 3 CREATION OF BOARD OF APPEALS (BOA)**

The Airport Board hereby establishes a Board of Appeals (BOA) for the purpose of determining the acceptability and adequacy of materials, equipment and methods of construction and for interpretation of these standards. The Airport Board shall adopt construction and fire prevention standards, which will be applicable throughout the Airport. The Construction and Fire Prevention Standards shall include but not be limited to the Building Code, Fire Code, Electrical Code, Mechanical Code, Plumbing Code, Fuel Gas Code and Energy Code and Part Nine of this Resolution for Oil and Gas Exploration and Production as adopted by the Airport Board and amended from time to time.

### **SECTION 4 COMPOSITION OF BOA**

The BOA shall consist of seven voting members who shall serve without compensation and shall be selected in the following manner:

- Place 1: An architect, registered to practice as an architect in the State of Texas - The selection of the architect shall be made alternatively by the Dallas and Fort Worth Chapters of the American Institute of Architects and shall be confirmed by the Airport Board. The initial term will be filled by a selection of the Dallas Chapter and will extend from the Airport Board's confirmation of the selection through December 31, 1990. Thereafter, terms will be for two years extending from January 1 of odd-numbered years through December 31 of even-numbered years.
- Place 2: An electrical engineer, registered to practice as a professional engineer in the State of Texas whose practice is or has been the design of electrical systems for buildings - The selection of the electrical engineer shall be made alternatively by the Dallas and Fort Worth Chapters of the Texas Society of Professional Engineers and shall be confirmed by the Airport Board. The initial term will be filled by a selection of the Fort Worth Chapter and will extend from the Airport Board's confirmation of the selection through December 31, 1990. Thereafter, terms will be for two years extending from January 1 of odd-numbered years through December 31 of even-numbered years.

- Place 3: A mechanical engineer, registered to practice as a professional engineer in the State of Texas whose practice is or has been the design of mechanical systems for buildings - The selection of the mechanical engineer shall be made alternatively by the Dallas and Fort Worth Chapters of the Texas Society of Professional Engineers and shall be confirmed by the Airport Board. The initial term will be filled by a selection of the Fort Worth Chapter and will extend from the Airport Board's confirmation of the selection through December 31, 1991. Thereafter, terms will be for two years extending from January 1 of even-numbered years through December 31 of odd-numbered years.
- Place 4: A structural engineer, registered to practice as a professional engineer in the State of Texas whose practice is or has been the design of structural systems for buildings - The selection of the structural engineer shall be made alternatively by the Dallas and Fort Worth Chapters of the Texas Society of Professional Engineers and shall be confirmed by the Airport Board. The initial term will be filled by a selection of the Fort Worth Chapter and will extend from the Airport Board's confirmation of the selection through December 31, 1991. Thereafter, terms will be for two years extending from January 1 of even-numbered years through December 31 of odd-numbered years.
- Place 5: A fire protection specialist - The selection of the fire protection specialist shall be made by the Dallas/Fort Worth Chapter of the Society of Fire Protection Engineers and shall be confirmed by the Airport Board. The initial term will extend from the Airport Board's confirmation of the selection through December 31, 1991. Thereafter, terms will be for two years extending from January 1 of even-numbered years through December 31 of odd-numbered years.
- Place 6: A design professional, registered to practice as an architect or as a professional engineer in the State of Texas, and whose profession relates to the design of facilities, structures or systems that are constructed – The selection of the design professional for Place 6 shall be made by the Dallas Metroplex Alumni Extension Chapter of the National Society of Black Engineers and shall be confirmed by the Airport Board. The initial term shall extend from the Airport Board's confirmation of the selection through December 31, 2005. Thereafter, terms will be for two years extending from January 1 of even-numbered years through December 31 of odd-numbered years.
- Place 7: A design professional registered to practice as an architect or as a professional engineer in the State of Texas, and whose profession relates to the design of facilities, structures or systems that are constructed – The

selection of the design professional for Place 7 shall be made by the Dallas-Fort Worth Chapter of the Society of Hispanic Professional Engineers and shall be confirmed by the Airport Board. The initial term will extend from the Airport Board's confirmation of the selection through December 31, 2004.\* Thereafter, terms will be for two years extending from January 1 of odd-numbered years through December 31 of even-numbered years.

There is no limit on the number of terms an individual may serve on the BOA; however, only in Places 5, 6 and 7 may an individual serve in consecutive terms. Any term scheduled to end on December 31, shall be automatically extended until a successor for that place is selected, confirmed, and sworn in.

In the event that any professional organization, designated to select a candidate to fill a term on the BOA, is unable to make such a selection, and the professional organization notifies the Building Official that a selection cannot be made, then the Building Official shall designate the unfilled seat as officially vacant, and it shall remain vacant until the next scheduled term for that seat.

## **SECTION 5 EX-OFFICIO MEMBERS**

The Building Official and the Fire Chief or their designated representatives shall be ex-officio non-voting members of the BOA. The BOA may make recommendations through the Building Official or Fire Chief to the Airport Board for amendments to the standards accordingly.

The Building Official of the Dallas/Fort Worth International Airport Board is the official in charge of the Code Compliance Section of the Airport Development and Engineering Department.

The Director of the Department of Public Safety of the Dallas/Fort Worth International Airport Board or his designee is hereby designated as the Fire Chief.

## **SECTION 6 MEETINGS: QUORUM**

All meetings of the BOA shall be open to the public except as permitted by law and as is in the interest of the Airport. Three (3) members of the BOA shall constitute a quorum to transact business. Every matter before the BOA for vote shall require for final passage the affirmative vote of a majority of the members present and voting. The first meeting of the BOA following its appointment shall be at such time and place as called by the Building Official. Thereafter the BOA shall hold meetings at such time and place as called by the Chairman or one lawfully acting in that capacity.

## **SECTION 7 BYLAWS AND RECORDS**

At its first meeting the BOA shall elect one of its members as Chairman, and he shall keep a record of the proceedings and decisions, and a copy of same shall be filed in the office of the Building Official. Each year thereafter, following the Airport Board's confirmation of the composition of the BOA, the BOA shall hold an organizational meeting, at which time it shall elect a Chairman before proceeding to other matters of business. The BOA shall establish its own rules of procedure and shall amend them from time to time as it deems necessary. The Building Official shall serve as Secretary to the BOA.

## **SECTION 8 AUTHORITY AND POWER**

The BOA shall have the authority and power to:

1. Hear appeals on interpretations by the Building Official of the Building Code, Electrical Code, Mechanical Code, Plumbing Code, Fuel Gas Code and Energy Code. The BOA may modify in whole or in part or may affirm the interpretation of the Building Official. The Building Official shall render a written interpretation within thirty (30) days of a request by a person who has been aggrieved by a decision of the Building Official. No interpretations shall be heard by the BOA until the Building Official has rendered a written interpretation.
2. Hear appeals on interpretations by the Fire Chief of the Fire Code. The BOA may modify in whole or in part or may affirm the interpretation of the Fire Chief. The Fire Chief shall render a written interpretation within thirty (30) days of a request by a person who has been aggrieved by a decision of the Fire Chief. No interpretations shall be heard by the BOA until the Fire Chief has rendered a written interpretation.
3. Approve alternate methods of construction and fire prevention where it is impractical to meet the adopted construction and fire prevention standards, provided that the BOA finds the same degree of suitability, strength, effectiveness, fire resistance, durability, sanitation and safety exists in the alternate method as intended by the standards.
4. Approve new methods of construction and fire prevention not covered by the construction and fire prevention standards, provided that the BOA finds the same degree of suitability, strength, effectiveness, fire resistance, durability, sanitation and safety exists in the new method as intended by the standards.

The BOA shall have no power to otherwise limit, modify or change these construction and fire prevention standards.

**SECTION 9  
RIGHT OF APPEAL**

Any person, firm, company or corporation aggrieved by any decision or order of the Building Official or Fire Chief may appeal such decision or order to the BOA. Every appeal must be in writing and must be filed in triplicate with the Building Official within thirty (30) days from the date of the decision or order appealed from. The BOA shall not consider any appeal that is filed after the thirty (30) day period. Such appeal shall contain appropriate reference to the decision or order appealed from, as well as the grounds for the appeal.

**SECTION 10  
AGENDA AND RECORDS**

The agenda for the BOA shall be prepared by the Building Official and shall be posted as required by law. All records and evidence pertinent to any appeal shall be transmitted to the BOA and to the aggrieved party prior to the hearing. Records of all appeals shall be kept in the office of the Building Official. The Building Official shall transmit copies of appeal records to the Fire Chief.

**SECTION 11  
HEARING**

The BOA shall fix a reasonable time for the hearing of an appeal and shall give notice of the hearing in writing to the parties in interest. Parties may appear before the BOA in person, by agent or by attorney. The BOA shall establish rules for the fair and efficient conduct of the hearing and the just resolution to an appeal. The BOA shall notify the appellant of its decision.

**SECTION 12  
STAY OF PROCEEDINGS**

An appeal shall stay all proceedings in connection with the decision or order appealed from, unless and until the Building Official or Fire Chief shall have certified to the BOA after notice of appeal has been filed that a stay would cause an unreasonable risk of harm to life or damage to property. Any work done contrary to the order of the Building Official or Fire Chief after filing an appeal hereunder, pending the determination of such appeal, shall be subject to removal or repair should the order be affirmed. The cost of removal or repair of the work done shall be borne solely by the person, firm, company or corporation who was responsible for the work without consideration of mitigating or extenuating circumstances.

**SECTION 13**  
**2006 INTERNATIONAL BUILDING CODE ADOPTED**

The Building Code of the Dallas-Fort Worth International Airport Board is hereby revised and amended to conform to the 2006 International Building Code of the International Code Council, Inc. except as amended by separate exhibit attached hereto and is hereby adopted as the Building Code and forms a part of the Construction and Fire Prevention Standards from the effective date hereof.

**SECTION 14**  
**2006 INTERNATIONAL FIRE CODE ADOPTED**

The Fire Code of the Dallas-Fort Worth International Airport Board is hereby revised and amended to conform to the 2006 International Fire Code of the International Code Council, Inc. except as further amended by separate exhibit attached hereto and is hereby adopted as the Fire Code and forms a part of the Construction and Fire Prevention Standards from the effective date hereof.

**SECTION 15**  
**2005 NATIONAL ELECTRICAL CODE ADOPTED**

The Electrical Code of the Dallas-Fort Worth International Airport Board is hereby revised and amended to conform to the 2005 National Electrical Code of the National Fire Protection Association and the 2006 ICC Electrical Code Administrative Provisions of the International Code Council, Inc. except as amended by separate exhibit attached hereto and together are hereby adopted as the Electrical Code and form a part of the Construction and Fire Prevention Standards from the effective date hereof.

**SECTION 16**  
**2006 INTERNATIONAL MECHANICAL CODE ADOPTED**

The Mechanical Code of the Dallas-Fort Worth International Airport Board is hereby revised and amended to conform to the 2006 International Mechanical Code of the International Code Council, Inc. except as amended by separate exhibit attached hereto and is hereby adopted as the Mechanical Code and forms a part of the Construction and Fire Prevention Standards from the effective date hereof.

**SECTION 17**  
**2006 INTERNATIONAL PLUMBING CODE ADOPTED**

The Plumbing Code of the Dallas-Fort Worth International Airport Board is hereby revised and amended to conform to the 2006 International Plumbing Code of the International Code Council, Inc. except as amended by separate exhibit attached hereto

and is hereby adopted as the Plumbing Code and forms a part of the Construction and Fire Prevention Standards from the effective date hereof.

**SECTION 18**  
**2006 INTERNATIONAL FUEL GAS CODE ADOPTED**

The Fuel Gas Code of the Dallas-Fort Worth International Airport Board is hereby revised and amended to conform to the 2006 International Fuel Gas Code of the International Code Council, Inc. except as amended by separate exhibit attached hereto and is hereby adopted as the Fuel Gas Code and forms a part of the Construction and Fire Prevention Standards from the effective date hereof.

**SECTION 19**  
**2006 INTERNATIONAL ENERGY CONSERVATION CODE ADOPTED**

The Energy Code of the Dallas-Fort Worth International Airport Board is hereby revised and amended to conform to the 2006 International Energy Conservation Code of the International Code Council, Inc. except as amended by separate exhibit attached hereto and is hereby adopted as the Energy Code and forms a part of the Construction and Fire Prevention Standards from the effective date hereof.

**SECTION 20**  
**REQUIRED PERMITS**

The following activities shall not be performed within the boundaries of the Dallas-Fort Worth International Airport unless a permit for such work has first been obtained from the building official.

1. Construction
2. Oil and Gas Exploration and Production
3. Erection or Alteration of Signs

A permit shall not be required for Airport Board maintenance-related construction work for replacement in like kind under either of the following conditions:

All of the work is performed by Airport Board personnel, and the cost of the work does not exceed \$50,000.

All or part of the work is contracted by the Airport Board, and the cost of the work does not exceed \$5,000.

## **SECTION 21 REQUIRED FEES**

All construction projects for which construction permits are required are subject to a construction permit fee and a plan review fee except where otherwise prohibited by law. Permit and plan review fees shall not be imposed for Airport Board construction projects funded from operating and maintenance funds or seized funds.

## **SECTION 22 LICENSES REQUIRED**

Contractors providing the following work within the boundaries of Dallas-Fort Worth International Airport shall be licensed respectively for the category of work performed as regulated by the following:

28 TEX. ADMIN. CODE, Part 1, Subchapter E, Fire Extinguisher Rules § 34.511, Fire Extinguisher Licenses

28 TEX. ADMIN. CODE, Part 1, Subchapter F, Fire Alarm Rules § 34.611, Licenses

28 TEX. ADMIN. CODE, Part 1, Subchapter G, Fire Sprinkler Rules § 34.710, Certificates of Registration

The Air Conditioning and Refrigeration Contractor License Law, Title 8, Occupations Code, Chapter 1302

The Plumbing License Law, Occupations Code, Chapter 1301

Irrigators. Occupations Code, Chapter 1903

Electricians, Title 8, Occupations Code, Chapter 1305

## **SECTION 23 ENFORCEMENT**

The Building Official and Fire Chief shall enforce and execute all decisions and orders of the BOA for which they are respectively responsible. Upon adoption by the Airport Board and the City Councils of the Cities of Dallas and Fort Worth, this resolution shall become effective and shall be enforceable in the municipal courts of a municipality within whose boundaries a violation occurs.

**SECTION 24  
SPECIAL ENACTMENT**

The provisions of this Resolution and the Codes which are a part hereof constitute a special enactment in effect only within the boundaries of the Dallas-Fort Worth International Airport, and are adopted in recognition of the unique and special requirements connected with the planning, building, improvement, maintenance, operation, regulation, protection and policing of the Dallas-Fort Worth International Airport. Neither the Resolution nor the Codes shall be construed to waive or set aside any provisions contained in any law of the State of Texas.

**SECTION 25  
CONFLICTING PROVISIONS**

This resolution shall be cumulative of all provisions of previous actions of the Airport Board except where the provisions of this resolution are in direct conflict with the provisions of previous Board Actions, in which event conflicting provisions of such previous Board Actions are hereby repealed.

**SECTION 26  
SEVERABILITY CLAUSE**

It is hereby declared to be the intention of the Airport Board that the sections, paragraphs, sentences, clauses and phrases of this resolution are severable, and if any phrase, clause, sentence, paragraph or section of this resolution shall be declared unconstitutional by the valid judgment or decree of any court of competent jurisdiction such unconstitutionality shall not affect any of the remaining phrases, clauses, sentences, paragraphs and sections of this resolution, since the same would have been enacted by the Airport Board without the incorporation in this resolution of any such unconstitutional phrase, clause, sentence, paragraph or section.

**SECTION 27  
PENAL CLAUSE**

Section 8.F. of the 1968 Contract and Agreement, as amended, between the City of Dallas, Texas and the City of Fort Worth, Texas, provides that the Dallas-Fort Worth International Airport Board shall have the power, by a duly adopted order, to adopt and enforce rules and regulations for the orderly, safe efficient and sanitary operation of the airport and to prescribe penalties for the breach of any rule or regulation not to exceed the maximum fines authorized by state law. State law currently authorizes fines of up to \$500 for all violations of the airport's rules and regulations, except for those violations relating to fire safety, public health and sanitation, or the dumping of refuse, for which the maximum fine is \$2,000, and except when another fine is fixed by state law. Each day that a violation is permitted to exist shall constitute a separate offense.

**SECTION 28  
SAVINGS CLAUSE**

All rights and remedies of the Airport Board are expressly saved as to any and all violations of the provisions of the Building Code, the Fire Code or any other codes affecting construction or fire prevention which have accrued at the time of the effective date of this resolution and, as to such accrued violations and all pending litigation, both civil and criminal, whether pending in court or not, under such codes, same shall not be affected by this resolution but may be prosecuted until final disposition by the courts.

**SECTION 29  
PUBLICATION**

The Building Official is hereby authorized to publish this resolution in pamphlet form for general distribution among the public, and the operative provisions of this resolution as so published shall be admissible in evidence in all courts without further proof than the production thereof. The Building Official is hereby directed to publish a caption of this Resolution which summarizes the purposes thereof for two (2) days in major newspapers of the Cities of Dallas and Fort Worth Texas, as authorized by V.T.C.A., Local Government Code '52.013.

**SECTION 30  
EFFECTIVE DATE**

This resolution shall be in full force and effect from and after its passage and publication as required by law and it is so ordained.

## PART TWO – BUILDING CODE AMENDMENTS

### SECTION 101.1 TITLE

Amend Section 101.1 to read as follows:

**101.1 Title.** The 2006 International Building Code as amended herein is the Building Code of Dallas-Fort Worth International Airport. References to the International Building Code shall be construed to reference the Building Code as adopted herein with its local amendments.

### SECTION 101.4 REFERENCED CODES

Amend Section 101.4 to read as follows:

**101.4 Referenced codes.** The other codes listed in Sections 101.4.1 through 101.4.7 (except 101.4.5) and referenced elsewhere in this code, when specifically adopted, shall be considered part of the requirements of this code to the prescribed extent of each such reference. Whenever amendments have been adopted to the referenced codes and standards, each reference to said code and standard shall be considered to reference the amendments as well. Any reference to NFPA 70 or the ICC *Electrical Code* shall mean the Electrical Code as adopted. Delete all references to the International Property Maintenance Code.

### SECTION 102.6 EXISTING STRUCTURES

Amend Section 102.6 to read as follows:

**102.6 Existing structures.** The legal occupancy of any structure existing on the date of adoption of this code shall be permitted to continue without change, except as specifically covered in this code, ~~the International Property Maintenance Code~~, or the Fire Code, or as is deemed necessary by the building official for the general safety and welfare of the occupants and the public.

**SECTION 103  
DEPARTMENT OF BUILDING SAFETY**

Amend Section 103.1 as follows:

**103.1 Creation of enforcement agency.** The department of building safety is hereby created, and the official in charge thereof shall be known as the building official. ~~References to the Department of Building Safety shall mean the Code Compliance Section of the Airport Development and Engineering Department.~~

**SECTION 105  
PERMITS**

Amend Section 105.1 as follows:

**105.1 Required.** ~~Refer to Part One, Section 20 for general permit requirements.~~ Any owner or authorized agent who intends to construct, enlarge, alter, repair, move, demolish or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the building official and obtain the required permit.

Delete Sections 105.1.1, Annual permit and Section 105.1.2, Annual permit records.

**SECTION 105.2  
WORK EXEMPT FROM PERMIT**

Amend Section 105.2 as follows:

**105.2 Work exempt from permit.** Exemptions from permit requirements of this code shall not be deemed to grant authorization for any work to be done in any manner in violation of the provisions of this code or any other laws or ordinances of this jurisdiction. Permits shall not be required for the following:

**Building:**

- ~~1. One-story detached accessory structures used as tool and storage sheds, play houses and similar uses, provided the floor area does not exceed 120 square feet (11m<sup>2</sup>).~~
- ~~2. Fences not over 6 feet (1829 mm) high.~~
- ~~3. Oil derricks.~~

- ~~4. Retaining walls that are not over 4 feet (1219 mm) in height measured from the bottom of the footing to the top of the wall, unless supporting a surcharge or impounding Class I, II or IIA liquids.~~
- ~~5. Water tanks supported directly on grade if the capacity does not exceed 5,000 gallons (18,925 L) and the ratio of height to diameter or width does not exceed 2:1.~~
- ~~6. Sidewalks and driveways not more than 30 inches (762 mm) above adjacent grade, and not over any basement or story below and are not part of an accessible route.~~
7. Painting, papering, tiling, carpeting, cabinets, counter tops and similar finish work if installation of such is a replacement in like kind and when not associated with other construction work.
8. Temporary motion picture, television and theater stage sets and scenery.
9. Prefabricated swimming pools accessory to a Group R-3 occupancy, as applicable in Section 101.2, which are less than 24 inches (610 mm) deep, do not exceed 5,000 gallons (18,925 L) and are installed entirely above ground.
10. Shade cloth structures constructed for nursery or agricultural purposes, not including service systems.
11. Swings or other playground equipment accessory to one- and two-family dwellings.
12. Window awnings supported by an exterior wall that do not project more than 54 inches (1372 mm) from the exterior wall and do not require additional support of Group R-3 and U occupancies.
13. Nonfixed and movable fixtures, cases, racks, counters and partitions not over 5 feet 9 inches (1753 mm) in height, **except in Airport terminal buildings.**

#### **Electrical:**

**Repairs and maintenance:** Minor repair work, including the replacement of lamps or the connection of approved portable electrical equipment to approved permanently installed receptacles.

~~**Radio and television transmitting stations:** The provisions of this code shall not apply to electrical equipment used for radio and television transmissions, but~~

~~do apply to equipment and wiring for a power supply and the installations of towers and antennas.~~

The remainder of Section 105.2 shall be unchanged.

## **SECTION 106.1 SUBMITTAL DOCUMENTS**

Amend the first paragraph under Section 106.1 to read as follows:

**106.1 Submittal documents.** Unless approved otherwise by the building official, construction documents, statement of special inspections and other data shall be submitted in ~~one or more~~ eight sets with each permit application. For building construction projects, provide on the drawings information required under Section 110.2 of this Code for Items 1, 2, 3, 7, 8, 9, 10 and 11. Vehicular parking count and building areas listed by floor level and occupancy group shall also be included. For all projects, include a north arrow and graphic scale where applicable. The construction documents shall be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed. Where special conditions exist, the building official is authorized to require additional construction documents to be prepared by a registered design professional.

## **SECTION 106.3.1 APPROVAL OF CONSTRUCTION DOCUMENTS**

Add the following sentence at the beginning Section 106.3.1:

**106.3.1 Approval of construction documents.** Where construction documents are required to be prepared by a registered design professional, a construction permit cannot be issued before the building official receives two sets of final construction documents sealed by the registered design professional.

## **SECTION 108 FEES**

Following Section 108.6, add Table 1A – Construction Permit and Plan Review Fees.

### **CONSTRUCTION PERMIT AND PLAN REVIEW FEES**

All construction projects for which construction permits are required are subject to a construction permit fee and a plan review fee except where otherwise prohibited by law. Refer to Part One, Section 21 for exceptions. The construction permit fee is based upon the value of all construction work for which the permit is issued, as well as all

finish work, painting, roofing, electrical, plumbing, heating, air conditioning, elevators, fire extinguishing systems and any other permanent equipment. Where proposed maintenance work is limited to replacement in like kind, and in the opinion of the Building Official a construction permit fee or plan review fee is not justified, the Building Official may waive such fees. The plan review fee is an additional fee equal to 65% of the construction permit fee. The following table shall be used to determine the construction permit fee. The plan review fee shall be added thereto. These fees shall be paid prior to the issuance of a construction permit unless otherwise approved.

VALUE OF CONSTRUCTION WORK	CONSTRUCTION PERMIT FEE (Add to these amounts 65% for Plan Review Fee)
\$1.00 to \$500.00	\$23.50
\$501.00 to \$2,000.00	\$23.50 for the first \$500.00 plus \$3.05 for each additional \$100.00, or fraction thereof, to and including \$2,000.00
\$2,001.00 to \$25,000.00	\$69.25 for the first \$2,000.00 plus \$14.00 for each additional \$1,000.00, or fraction thereof, to and including \$25,000.00
\$25,001.00 to \$50,000.00	\$391.75 for the first \$25,000.00 plus \$10.10 for each additional \$1,000.00, or fraction thereof, to and including \$50,000.00
\$50,001.00 to \$100,000.00	\$643.75 for the first \$50,000.00 plus \$7.00 for each additional \$1,000.00, or fraction thereof, to and including \$100,000.00
\$100,001.00 to \$500,000.00	\$993.75 for the first \$100,000.00 plus \$5.60 for each additional \$1,000.00, or fraction thereof, to and including \$500,000.00
\$500,001.00 to \$1,000,000.00	\$3,233.75 for the first \$500,000.00 plus \$4.75 for each additional \$1,000.00, or fraction thereof, to and including \$1,000,000.00
\$1,000,001.00 and up	\$5,608.75 for the first \$1,000,000.00 plus \$3.65 for each additional \$1,000.00, or fraction thereof

**Other Inspections and Fees:**

(These fees are payable upon services rendered and receipt of invoice.)

- 1. Inspections outside of normal business hours.....\$47.00 per hour<sup>1</sup>  
(minimum charge – two hours)
- 2. Reinspection fees .....\$47.00 per hour<sup>1</sup>
- 3. Inspections for which no fee is specifically indicated..... \$47.00 per hour<sup>1</sup>  
(minimum charge – one-half hour)
- 4. Additional plan review for changes, additions  
or revisions to plans.....\$47.00 per hour<sup>1</sup>  
(minimum charge – one-half hour)
- 5. For use of outside consultants for plan checking,  
inspections or both..... Actual costs<sup>2</sup>

<sup>1</sup>Or the total hourly cost to the Airport Board, whichever is the greatest. This cost shall include supervision, overhead, equipment, hourly wages and fringe benefits of the employees involved.

<sup>2</sup>Actual costs include administrative and overhead costs.

**SECTION 110.2  
CERTIFICATE ISSUED**

Delete from list at the bottom of Section 110.2 Items 7 through 11.

**SECTION 112  
BOARD OF APPEALS**

Amend Section 112 to read as follows:

**Section 112 – Board of Appeals** Refer to Part One, Construction and Fire Prevention Standards Resolution for Board of Appeals.

**SECTION 113.4  
VIOLATION PENALTIES**

Add the following sentence at the bottom of Section 113.4:

Refer to Part One, Construction and Fire Prevention Standards Resolution, Section 27, Penal Clause.

## SECTION 202 DEFINITIONS

Following the definition of **ADDITION**, add the following definition:

**ADDRESSABLE FIRE DETECTION SYSTEM.** Any fire alarm system capable of providing identification of each individual alarm-initiating device. The identification shall be in clear English and shall identify the type and location of the device in alarm. The system shall have the ability of alarm verification.

Following the definition of **AGRICULTURE BUILDING**, add the following definition:

**AIRPORT.** Airport is the area within the boundaries of the Dallas-Fort Worth International Airport. Following the definition of **ADDITION**, add the following definition:

Following the definition of **ALTERNATING TREAD DEVICE**, add the following definition:

**ANALOG INTELLIGENT ADDRESSABLE FIRE DETECTION SYSTEM.** Any system capable of calculating a change in value by directly measurable quantities (voltage, resistance, etc.) at the sensing point. The physical analog may be conducted at the sensing point or at the main control panel. The system shall be capable of compensating for long-term changes in sensor response while maintaining a constant sensitivity. The compensation shall have a preset point at which a detector maintenance signal shall be transmitted to the control panel. The sensor shall remain capable of detecting and transmitting an alarm while in maintenance alert.

Following the definition of **HIGHLY TOXIC**, add the following definition:

**HIGH-RISE BUILDINGS.** Buildings with a floor used for human occupancy located more than 55 feet (16 764 mm) above the lowest level of fire department vehicle access.

Amend the definition of **SELF-SERVICE STORAGE FACILITY** to read as follows:

**SELF-SERVICE STORAGE FACILITY.** Real property designed and used for the purpose of renting or leasing individual storage spaces to customers for the purpose of storing and removing personal property on a self-service basis.

## SECTION 403.1 APPLICABILITY FOR HIGH-RISE BUILDINGS

Amend Section 403.1 as follows: (Exceptions 1 through 5 to remain and add Exception 6.)

**403.1 Applicability.** The provisions of this section shall apply to buildings having occupied floors located more than ~~75 55~~ feet ~~(22 860 mm)~~ (16 764 mm) above the lowest level of fire department vehicle access.

**Exceptions:**

6. Train platforms for fixed guideway transit systems in accordance with Section 412.7.

**SECTION 412.6  
FUELING RAMP DRAINAGE AND AIRCRAFT LOADING WALKWAYS**

Add new section as follows:

**412.6 Aircraft fueling ramp drainage and aircraft loading walkways.** Except for references to airport terminal buildings, comply with NFPA 415, 2008 Edition for aircraft fueling ramp drainage and aircraft loading walkways.

**Exceptions:**

1. Attached or adjacent fixed loading walkways, gate houses and similar structures accessory to airport terminal buildings may be constructed of Type II-A Construction, provided the floor area of individual structures does not exceed 500 square feet. An approved automatic sprinkler system in accordance with Section 903.3.1.1 shall be allowed to be substituted for 1-hour fire-resistance-rated construction. If the automatic sprinkler system substitution is provided, exterior walls of such structures shall not be required to be of 1-hour fire-resistance-rated construction and openings in such walls shall not be required to be protected.
2. Canopies over baggage conveyors attached to or adjacent to airport terminal buildings may be of Type II-B Construction.

**SECTION 412.7  
FIXED GUIDEWAY TRANSIT SYSTEMS**

Add new section as follows:

**412.7 Fixed guideway transit systems.** Fixed guideway transit systems shall comply with NFPA 130, 2000 Edition.

**SECTION 903.2  
AUTOMATIC SPRINKLER SYSTEMS – WHERE REQUIRED**

Delete exception in Section 903.2 for spaces and areas in telecommunications buildings.

**SECTION 903.2.7.1  
AUTOMATIC SPRINKLER SYSTEMS – GROUP R OCCUPANCIES**

Add Section 903.2.7 as follows:

**[F] 903.2.7.1 Fire sprinklers.** An approved automatic sprinkler system shall be installed in new one and two-family dwellings and town homes constructed in accordance with Section 903.3.1.3.

**SECTION 903.2.10.3  
BUILDINGS 55 FEET OR MORE IN HEIGHT**

Amend Section 903.2.10.3 to read as follows and delete two exceptions:

**[F] 903.2.10.3 Buildings more than 55 feet in height.** An automatic sprinkler system shall be installed throughout buildings with a floor level, ~~other than penthouses in compliance with Section 1509 having an occupant load of 30 or more~~ that is located 55 feet (16 764 mm) or more above the lowest level of fire department vehicle access.

**Exception:**

- ~~1. Airport control towers~~
2. Open parking structures.
- ~~3. Occupancies in Group F-2.~~

**SECTION 903.2.10.4  
HIGH-PILED COMBUSTIBLE STORAGE**

Add Section 903.2.10.4 as follows:

**[F] 903.2.10.4 High-piled combustible storage.** For any building with a clear height exceeding 12 feet (4572 mm), see Chapter 23 to determine if those provisions apply.

**SECTION 903.2.10.5  
SPRAY BOOTHS AND ROOMS**

Add Section 903.2.10.5 as follows:

**[F] 903.2.10.5 Spray booths and rooms.** Spray booths and rooms shall be protected by an approved automatic fire-extinguishing system.

**SECTION 903.2.10.6  
BUILDING AREAS EXCEEDING 6,000 SQUARE FEET**

Add Section 903.2.10.6 as follows:

**[F] 903.2.10.6 Buildings with floor areas exceeding 6,000 square feet.** An automatic sprinkler system shall be installed throughout all buildings with a building area exceeding 6,000 square feet. For purposes of this provision, fire walls shall not define separate buildings.

**Exceptions:**

1. Open parking garages
2. Group A-5 Occupancies

**SECTION 903.2.10.7  
SELF-SERVICE STORAGE FACILITY**

Add Section 903.2.10.7 as follows:

**[F] 903.2.10.7 Self-service storage facilities.** An approved automatic sprinkler system shall be installed throughout all self-storage facilities.

**Exception:**

Open parking garages

**SECTION 907.2  
FIRE ALARM AND DETECTION SYSTEMS – WHERE REQUIRED**

Add the following two paragraphs after the second paragraph under Section 907.2:

All buildings or occupancies, occupied, operated, maintained or monitored by the Dallas-Fort Worth International Airport Board shall have a complete operational manual and automatic fire alarm system in accordance with this code. The system shall be

designed and installed in accordance with the DFW Airport Design Criteria Manual and applicable standards.

All buildings or occupancies, other than those described in the preceding paragraph, hereafter constructed or moved on to the airport and having a total floor area of 1,000 square feet or more, regardless of height or occupant load shall have a complete operational manual and automatic fire alarm system in accordance with the requirements of this code.

**Exceptions:**

1. Open parking garages may use other approved means for fire department notification.
2. Temporary structures or buildings erected for less than 365 days when approved by the fire chief.

**SECTION 907.2.1.1  
FIRE ALARM ACTIVATION – GROUP A OCCUPANCIES**

Amend Section 907.2.1.1 to read as follows:

**[F] 907.2.1.1 System initiation in Group A occupancies with an occupant load of 1,000 or more.** Activation of the fire alarm in Group A occupancies with an occupant load of 1,000 or more shall initiate a signal using an emergency voice/alarm communications system in accordance with NFPA 72.

**Exceptions:**

1. Where approved, the prerecorded announcement is allowed to be manually deactivated for a period of time, not to exceed 3 minutes, for the sole purpose of allowing a live voice announcement from an approved, constantly attended location.
2. Where approved by the code official in airport terminal buildings, and where the fire alarm is monitored directly by the Dallas/Fort Worth International Airport Board Department of Public Safety, the activation of the fire alarm notification signal shall be manually initiated by emergency responders.

**SECTION 907.2.12  
HIGH-RISE BUILDINGS – FIRE ALARM SYSTEM**

Amend Section 907.2.12 as follows with the exceptions unchanged:

**[F] 907.2.12 High-rise buildings.** Buildings having floors used for human occupancy located more than ~~75 55~~ feet ~~(22-860 mm)~~ (16 764 mm) above the lowest level of fire department vehicle access shall be provided with an automatic fire alarm system and an emergency voice/alarm communications system in accordance with Section 907.2.12.2.

### **SECTION 907.3 MANUAL FIRE ALARM BOXES**

Amend Section 907.3 to read as follows:

**[F] 907.3 Manual fire alarm boxes.** Manual fire alarm boxes shall be installed in accordance with Sections 907.3.1 through 907.3.5. ~~Manual alarm actuating devices shall be an approved double action type.~~

#### **SECTION 907.3.1 MANUAL FIRE ALARM BOXES – LOCATION**

Amend Section 907.3.1 to read as follows:

**[F] 907.3.1 Location.** Manual fire alarm boxes shall be located not more than 5 feet (1524 mm) from the entrance to each exit. ~~Additional manual fire alarm boxes shall be located so that travel distance to the nearest box does not exceed 200 feet (60-960 mm).~~

#### **SECTION 907.8.2 HIGH-RISE BUILDINGS – FIRE ALARM ZONES**

Amend Section 907.8.2 as follows:

**907.8.2 High-rise buildings.** In buildings used for human occupancy that have floors located more than ~~75 55~~ feet ~~(22-860)~~ (16 764 mm) above the lowest level of fire department vehicle access, a separate zone by floor shall be provided all of the following types of alarm initiating devices where provided.

1. Smoke detectors.
2. Sprinkler water-flow devices.
3. Manual fire alarm boxes.
4. Other approved types of automatic fire detection devices or suppression systems.

#### **SECTION 1003.5 ELEVATION CHANGE**

Amend Exception 1 under Section 1003.5 to read as follows:

1. A single step with a maximum height of 7 inches (178 mm) is permitted for buildings with occupancies in Groups F, H, R-2 and R-3 and Groups S and U at exterior doors not required to be accessible by Chapter 11, **and at entrances to mechanical penthouses from roofed areas, the door sill elevation may be up to 8 inches (203 mm) above the elevation of the landing on either or both sides of the door.**

### **SECTION 1004.3 POSTING OF OCCUPANT LOAD**

Amend Section 1004.3 to read as follows:

**1004.3 Posting of occupant load.** Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent. **Assembly occupancies within airport terminal buildings are not required to have the occupant load posted unless required by the Building Official.**

### **SECTION 1020.1.7 SMOKEPROOF ENCLOSURES**

Amend Section 1020.1.7 as follows:

**10.20.1.7 Smokeproof enclosures.** In buildings required to comply with Section 403 or 405, each of the exits of a building that serves stories where the floor surface is located more than **75 55 feet (22 860 mm) (16 764 mm)** above the lowest level of fire department vehicle access or more than 30 feet (9144 mm) below the level of exit discharge serving such floor levels shall be a smokeproof enclosure or pressurized stairway in accordance with Section 909.20.

#### **Exception:**

**Fixed guideway train stations.**

### **CHAPTER 11 ACCESSIBILITY**

Replace Chapter 11 as follows:

**Spaces and elements of buildings and facilities shall be designed and constructed to standards consistent with the Texas Accessibility Standards as administered by the Texas Department of Licensing and Regulation, except for the following:**

**Unisex toilet rooms.** Assembly areas shall be provided with one unisex toilet room for each instance where the total fixture count (water closets and urinals) in a set of men and women's toilet rooms exceeds 20 fixtures. In assembly areas of airport terminal buildings, one unisex toilet room shall be provided in each instance where the total fixture count (water closets and urinals) in a set of men and women's toilet rooms exceeds 6 fixtures. The unisex toilet room shall be located adjacent to the men and women's toilet rooms, which are used to determine that the unisex toilet room is required

## **CHAPTER 29 PLUMBING SYSTEMS**

Replace Chapter 29 as follows:

Plumbing systems and the minimum number of plumbing fixtures shall comply with the Plumbing Code.

### **SECTION 3002.4 ELEVATOR CAR TO ACCOMMODATE AMBULANCE STRETCHER**

Amend Section 3002.4 to read as follows:

**3002.4 Elevator car to accommodate ambulance stretcher.** Where elevators are provided in buildings four or more stories above grade plane or four or more stories below grade plane, at least one elevator shall be provided for fire department emergency access to all floors. The elevator car shall be of such size and arrangement to accommodate a ~~24- 31-~~ by ~~84- 90-inch (610-mm by 1930-mm)~~ (788 mm by 2068 mm) ambulance stretcher in the horizontal open position and shall be identified by the international symbol for emergency medical services (star of life). The symbol shall not be less than 3 inches (76 mm) high and shall be placed inside on both sides of the hoistway door frame.

## **CHAPTER 35 REFERENCED STANDARDS**

Amend the NFPA standard reference number for National Fire Alarm Code as follows:

### **NFPA**

Standard Reference Number ~~72-02~~ 72-07

National Fire Alarm Code

## ADOPTION OF APPENDIX CHAPTER H SIGNS

Appendix Chapter H – Signs is specifically adopted as part of the Building Code.

### SECTION H-101.2 SIGNS EXEMPT FROM PERMITS

Amend Section H101.2 as follows:

**H- 101.2 Signs exempt from permits.** The following signs are exempt from the requirements to obtain a permit before erection:

- ~~1. Painted nonilluminated signs.~~
- ~~2. Temporary signs announcing the sale or rent of property.~~
3. Signs erected by transportation authorities.
- ~~4. Projecting signs not exceeding 2.5 square feet (0.23 m<sup>2</sup>).~~
5. The changing of movable parts of an approved sign that is designed for such changes, or the repainting or repositioning of display matter shall not be deemed an alteration.

### SECTION H105.2 PERMITS, DRAWINGS AND SPECIFICATIONS FOR SIGNS

Amend Section H105.2 as follows:

**H105.2 Permits, drawings and specifications.** Where a permit is required, as provided in ~~Chapter 4 Part One, Section 20~~, construction documents shall be required. These documents shall show the dimensions, material and required details of construction, including loads, stresses and anchors.

## PART THREE – FIRE CODE AMENDMENTS

### SECTION 101.1 TITLE

Amend Section 101.1 to read as follows:

**101.1 Title.** The 2006 International Fire Code as amended herein is the Fire Code of Dallas-Fort Worth International Airport. References to International Fire Code shall be construed to reference the Fire Code as adopted herein with its local amendments.

### SECTION 102.6 REFERENCED CODES AND STANDARDS

Amend Section 102.6 to read as follows:

**102.6 Referenced codes and standards.** The codes and standards referenced in this code shall be those that are listed in Chapter 45, and such codes, when specifically adopted, and standards shall be considered part of the requirements of this code to the prescribed extent of each such reference. Where differences occur between the provisions of this code and the referenced standards, the provisions of this code shall apply. Whenever amendments have been adopted to the referenced codes and standards, each reference to said code and standard shall be considered to reference the amendments as well. Any reference to NFPA 70 or the ICC Electrical Code shall mean the Electrical Code as adopted.

### SECTION 103.1 DEPARTMENT OF FIRE PREVENTION

Amend Section 103.1 as follows:

**103.1 General.** The department of fire prevention is established within the jurisdiction under the direction of the code official. The function of the department shall be the implementation, administration and enforcement of the provisions of this code. References to the department of fire prevention shall mean the Department of Public Safety, Fire Prevention Office.

### SECTION 105.4.1 CONSTRUCTION DOCUMENTS – SUBMITTALS

Amend Section 105.4.1 to read as follows:

**105.4.1 Submittals.** Construction documents required by the Fire Code shall be submitted in two sets to the Fire Prevention Office. The construction documents shall be legible and scalable and shall be prepared by a design professional as required by Texas law.

**SECTION 105.6.7  
COMBUSTIBLE DUST-PRODUCING OPERATIONS**

Amend Section 105.6.7 to read as follows:

**105.6.7 Combustible dust-producing operations.** Combustible dust-producing operations, as defined in this code, shall be prohibited within the airport.

**SECTION 105.6.18  
FRUIT AND CROP RIPENING**

Amend Section 105.6.18 to read as follows:

**105.6.18 Fruit and crop ripening.** Fruit and crop ripening operations using ethylene or other flammable gases shall be prohibited within the airport.

**SECTION 105.6.30  
OPEN BURNING**

Delete exception for Recreational fires.

**SECTION 105.6.33  
ORGANIC COATINGS**

Amend Section 105.6.33 to read as follows:

**105.6.33 Organic coatings.** The manufacturing or application of organic coatings, as defined in this code, shall be prohibited within the airport.

**SECTION 105.6.37  
PYROXYLIN PLASTICS**

Amend Section 105.6.37 as follows:

**105.6.37 Pyroxylin plastics.** An operational permit is required for storage or handling of ~~more than 25 pounds (11 kg)~~ any amount of cellulose nitrate (pyroxylin) plastics and for the assembly or manufacture of articles involving pyroxylin plastics.

**SECTION 107.2.2  
REINSPECTION AND TESTING**

Add a second paragraph under Section 107.2.2 to read as follows:

Fees for reinspections or for inspections outside of normal business hours shall be reimbursed as required by the fire chief in accordance with the Building Code, Section 108 – Fees.

**SECTION 108  
BOARD OF APPEALS**

Amend Section 108 to read as follows:

**108 Board of appeals.** Refer to Part One, Construction and Fire Prevention Standards Resolution for Board of Appeals.

**SECTION 109.3  
VIOLATION PENALTIES**

Amend Section 109.3 to read as follows:

**109.3 Violation penalties.** Refer to Part One, Construction and Fire Prevention Standards Resolution, Section 27, Penal Clause.

**SECTION 202  
DEFINITIONS**

Following the definition of **ACCESSIBLE MEANS OF EGRESS**, add the following definition:

**ADDRESSABLE FIRE DETECTION SYSTEM.** Any fire alarm system capable of providing identification of each individual alarm-initiating device. The identification shall be in clear English and shall identify the type and location of the device in alarm. The system shall have the ability of alarm verification.

Following the definition of **AMMONIUM NITRATE**, add the following definition:

**ANALOG INTELLIGENT ADDRESSABLE FIRE DETECTION SYSTEM.** Any system capable of calculating a change in value by directly measurable quantities (voltage, resistance, etc.) at the sensing point. The physical analog may be conducted at the sensing point or at the main control panel. The system shall be capable of compensating for long-term changes in sensor response while maintaining a constant sensitivity. The compensation shall have a preset point at which a detector maintenance

signal shall be transmitted to the control panel. The sensor shall remain capable of detecting and transmitting an alarm while in maintenance alert.

Following the definition of **HIGH PILED STORAGE AREA**, add the following definition:

**HIGH-RISE BUILDINGS.** Buildings with a floor used for human occupancy located more than 55 feet (16 764 mm) above the lowest level of fire department vehicle access.

Following the definition of **SELF-SERVICE MOTOR FUEL-DISPENSING FACILITY** add the following definition:

**SELF-SERVICE STORAGE FACILITY.** Real property designed and used for the purpose of renting or leasing individual storage spaces to customers for the purpose of storing and removing personal property on a self-service basis

#### **SECTION 307.4.1 BONFIRES**

Amend Section 307.4.1 to read as follows:

**307.4.1 Bonfires.** Bonfires shall be prohibited within the airport.

#### **SECTION 503.1.1 FIRE APPARATUS ACCESS ROADS – BUILDINGS AND FACILITIES**

Amend Section 503.1.1 as follows: (Exceptions remain in effect.)

**503.1.1 Buildings and facilities.** Approved fire apparatus access roads shall be provided for every facility, building or portion of a building hereinafter constructed or moved into or within the jurisdiction. The fire apparatus access road shall comply with the requirements of this section and shall extend to within 150 feet (45 720 mm) of all portions of the facility.

#### **SECTION 503.2.1 FIRE APPARATUS ACCESS ROADS – DIMENSIONS**

Amend Section 503.2.1 to read as follows:

**503.2.1 Dimensions.** Fire apparatus access roads shall have an unobstructed width of not less than ~~20 22 feet (6096 mm)~~ (6706 mm), except for approved security gates in accordance with Section 503.6, and an unobstructed vertical clearance of not less than ~~13 feet 6 inches 14 feet (4115 mm)~~ (4267 mm).

**SECTION 508.5.1  
FIRE HYDRANT SYSTEMS – WHERE REQUIRED**

Delete Section 508.5.1 including exceptions and substitute the following:

**508.5.1 Where required.** The location, number and type of fire hydrants connected to a water supply capable of delivering the required fire flow shall be provided on the public street or on the site to be protected or both as required by the fire chief. Fire hydrants shall be installed at intervals not to exceed 250 feet (76 200 mm) along new roadways, and at such locations that no part of a building exterior wall is in excess of a hose lay, 300 feet (91 440 mm) in length from the hydrant as measured along an approved route around the exterior of the building.

**SECTION 704.1  
FLOOR OPENINGS AND SHAFTS**

Section 704.1; amend section to read as follows:

**704.1 Enclosure.** Interior vertical shafts, including but not limited to stairways, elevator hoistways, service and utility shafts, that connect two or more stories of a building shall be enclosed or protected **in accordance with the codes in effect at the time of construction but, regardless of when constructed, not less than** as specified in Table 704.1.

**SECTION 903.2  
AUTOMATIC SPRINKLER SYSTEMS – WHERE REQUIRED**

Delete the exception under Section 903.2.

**SECTION 903.2.7.1  
GROUP R**

Add Section 903.2.7.1 as follows:

903.2.7.1 Fire Sprinklers. An approved automatic fire sprinkler system shall be installed in new one- and two-family dwellings and townhomes constructed under the International Residential Code in accordance with Section 903.3.1.3.

**SECTION 903.2.10.3  
BUILDINGS 55 FEET OR MORE IN HEIGHT**

Amend Section 903.2.10.3 to read as follows:

**903.2.10.3 Buildings more than 55 feet in height.** An automatic sprinkler system shall be installed throughout buildings with a floor level, **other than penthouses in compliance with Section 1509 of the Building Code, located more than 55 feet (16 764 mm)** above the lowest level of fire department vehicle access.

**Exceptions:**

- ~~1. Airport control towers.~~
2. Open parking structures.
- ~~3. Occupancies in Group F-2.~~

**SECTION 903.2.10.4  
HIGH-PILED COMBUSTIBLE STORAGE**

Add Section 903.2.10.4 as follows:

**903.2.10.4 High-piled combustible storage.** For any building with a clear height exceeding 12 feet (4572 mm), see Chapter 23 to determine if those provisions apply.

**SECTION 903.2.10.5  
SPRAY BOOTHS AND ROOMS**

Add Section 903.2.10.5 as follows:

**903.2.10.5 Spray booths and rooms.** Spray booths and rooms shall be protected by an approved automatic fire-extinguishing system.

**SECTION 903.2.10.6  
BUILDINGS WITH A FLOOR AREA EXCEEDING 6,000 SQUARE FEET**

Add Section 903.2.10.6 as follows:

**903.2.10.6 Buildings with a floor area exceeding 6,000 square feet.** An automatic sprinkler system shall be installed throughout all buildings with a building area exceeding 6,000 square feet. For the purpose of this provision, fire walls shall not define separate buildings.

**Exceptions:**

1. Open parking garages.
2. Group A-5 Occupancies.

**SECTION 903.2.14  
SELF-SERVICE STORAGE FACILITY**

Add to Section 903.2.14

**903.2.14 Self-service storage facilities.** An approved automatic sprinkler system shall be installed throughout all self-storage facilities.

**SECTION 905.2  
STANDPIPE SYSTEMS - INSTALLATION STANDARD**

Amend Section 905.2 to read as follows:

**905.2 Installation standard.** Standpipe systems shall be installed in accordance with this section and NFPA 14. **New manual dry standpipe systems shall be supervised with a minimum of 10 psig and a maximum of 40 psig air pressure and shall be equipped with a high/low alarm.**

**SECTION 907.2  
FIRE ALARM AND DETECTION SYSTEMS – WHERE REQUIRED**

Add the following two paragraphs after the second paragraph under Section 907.2.

**All buildings or occupancies, occupied, operated, maintained or monitored by the Dallas-Fort Worth International Airport Board shall have a complete operational manual and automatic fire alarm system in accordance with this code. The system shall be designed and installed in accordance with the DFW Airport Design Criteria Manual and applicable standards.**

**All buildings, other than those described in the preceding paragraph, hereafter constructed or moved on to the airport and having a total floor area of 1,000 square feet or more, regardless of height or occupant load, shall have a complete operational manual and automatic fire alarm system in accordance with the occupancy requirements of this code.**

**Exceptions:**

- 1. Open parking garages may use other approved means for fire department notification.**
- 2. Temporary structures or buildings erected for less than 365 days when approved by the fire chief.**

**SECTION 907.2.1.1  
FIRE ALARM ACTIVATION – GROUP A OCCUPANCIES**

Add Exception 2 under Section 907.2.1.1 to read as follows:

**907.2.1.1 System initiation in Group A occupancies with an occupant load of 1,000 or more.** Activation of the fire alarm in Group A occupancies with an occupant load of 1,000 or more shall initiate a signal using an emergency voice/alarm communications system in accordance with NFPA 72.

**Exceptions:**

1. Where approved, the prerecorded announcement is allowed to be manually deactivated for a period of time, not to exceed 3 minutes, for the sole purpose of allowing a live voice announcement from an approved, constantly attended location.
2. Where approved by the code official in airport terminal buildings, and where the fire alarm is monitored directly by the Dallas/Fort Worth International Airport Board Department of Public Safety, the activation of the fire alarm notification signal shall be manually initiated by emergency responders.

**SECTION 907.2.12  
HIGH-RISE BUILDINGS**

With exceptions unchanged, amend Section 907.2.12 to read as follows:

**907.2.12 High-rise buildings.** Buildings having floors used for human occupancy located more than ~~75~~ 55 feet ~~(22 860)~~ (16 764 mm) above the lowest level of fire department vehicle access shall be provided with an automatic fire alarm system and an emergency voice/alarm communication system in accordance with Section 907.2.12.2.

**SECTION 907.4  
MANUAL FIRE ALARM BOXES**

Amend Section 907.4 to read as follows:

**907.4 Manual fire alarm boxes.** Manual fire alarm boxes shall be installed in accordance with Sections 907.4.1 through 907.4.5. **Manual alarm actuating devices shall be of an approved double action type.**

**SECTION 907.4.1  
MANUAL FIRE ALARM BOXES – LOCATION**

Amend Section 907.4.1 to read as follows:

**907.4.1 Location.** Manual fire alarm boxes shall be located not more than 5 feet (1524 mm) from the entrance to each exit. ~~Additional manual fire alarm boxes shall be located so that the travel distance to the nearest box does not exceed 200 feet (60 960 mm).~~

**SECTION 907.9.2  
FIRE ALARM ZONES – HIGH-RISE BUILDINGS**

Amend Section 907.9.2 to read as follows:

**907.9.2 High-rise buildings.** In buildings with a floor used for human occupancy that is located more than ~~75 55~~ feet (~~22 860 mm~~) (16 764 mm) above the lowest level of fire department vehicle access, a separate zone by floor shall be provided for all of the following types of alarm-initiating devices where provided:

1. Smoke detectors.
2. Sprinkler water-flow devices.
3. Manual fire alarm boxes.
4. Other approved types of automatic fire detection devices or suppression systems.

**SECTION 1003.5  
ELEVATION CHANGE**

Amend Exception 1 under Section 1003.5 to read as follows:

1. A single step with a maximum height of 7 inches (178 mm) is permitted for buildings with occupancies in Groups F, H, R-2 and R-3 and Groups S and U at exterior doors not required to be accessible by Chapter 11, ~~and at entrances to mechanical penthouses from roofed areas, the door sill elevation may be up to 8 inches (203 mm) above the elevation of the landing on either or both sides of the door.~~

**SECTION 1004.3  
POSTING OF OCCUPANT LOAD**

Amend Section 1004.3 to read as follows:

**[B] 1004.3 Posting of occupant load.** Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent. **Assembly occupancies within airport terminal buildings are not required to have the occupant load posted unless required by the Building Official**

**SECTION 1020.1.7  
SMOKEPROOF ENCLOSURES**

Amend Section 1020.1.7 as follows:

**10.20.1.7 Smokeproof enclosures.** In buildings required to comply with Section 403 or 405, each of the exits of a building that serves stories where the floor surface is located more than **75 55 feet (~~22-860 mm~~) (16 764 mm)** above the lowest level of fire department vehicle access or more than 30 feet (9144 mm) below the level of exit discharge serving such floor levels shall be a smokeproof enclosure or pressurized stairway in accordance with Section 909.20.

**Exception:**

**Fixed guideway train stations.**

**SECTION 2705.1.8  
HAZARDOUS MATERIALS – FIRE EXTINGUISHING SYSTEMS**

Add a second paragraph under Section 2705.1.8 to read as follows:

**Gas cabinets, exhaust enclosures and exhaust ducts with a cross sectional dimension of 10 inches (255 mm) or greater shall be internally sprinklered.**

**SECTION 3301  
EXPLOSIVES AND FIREWORKS – GENERAL**

Add Section 3301- General as follows:

**3301 General.** The manufacture and sale of explosive material shall be prohibited within the airport.

**SECTION 3301.2.4  
FINANCIAL RESPONSIBILITY**

Amend Section 3301.2.4 to read as follows:

**3301.2.4 Financial responsibility.** Before a permit is issued, as required by Section 3301.2, the applicant shall file with the jurisdiction a corporate surety bond in the principal sum of ~~\$100,000~~ **\$1,000,000** or a public liability insurance policy for the same amount, for the purpose of the payment of all damages to persons or property which arise from, or are caused by, the conduct of any act authorized by the permit upon which any judicial judgment results. The code official is authorized to specify a greater or lesser amount when, in his or her opinion, conditions at the location of use indicate a greater or lesser amount is required. Government entities shall be exempt from this bond requirement.

**SECTION 3406.3.1.3.3  
NATURAL GAS PIPELINE SETBACK FROM BUILDINGS**

Add Section 3406.1.3.3 to read as follows:

**3406.3.1.3.3 Natural gas pipeline setback from buildings.** No building hereinafter erected shall be located within 50 feet (15 240 mm) of a natural gas gathering or transmission pipeline.

**SECTION 3703.2.5  
OUTDOOR STORAGE AND WEATHER PROTECTION**

Add an exception under Section 3703.2.5 to read as follows:

**Exception:**

Sprinklers are not required for certain water reactive materials when sprinklers would not be effective in controlling the fire.

**CHAPTER 45  
REFERENCED STANDARDS**

Amend the NFPA standard reference number for National Fire Alarm Code as follows:

**NFPA**

Standard Reference Number ~~72-02~~ **72-07**

National Fire Alarm Code

**ADOPTION OF APPENDIX CHAPTERS**

The following appendix chapters are specifically adopted as part of the Fire Code.

**Appendix B** Fire Flow Requirements for Buildings

**Appendix C** Fire Hydrant Locations and Distribution (Except hydrant spacing as required by Section 508.5.1.)

**Appendix D** Fire Apparatus Access Roads (except that minimum width of fire apparatus access roads shall be in accordance with Section 503.2.1 of the Fire Code)

**Appendix G** Cryogenic Fluids – Weight and Volume Equivalents

## PART FOUR – ELECTRICAL CODE AMENDMENTS

### Local Amendments to the 2006 International Code Council Electrical Code Administrative Provisions

#### SECTION 101.1 TITLE

Amend Section 101.1 to read as follows:

**101.1 Title.** The 2005 National Electrical Code with the 2006 ICC Electrical Code Administrative Provisions as amended herein is the Electrical Code of Dallas-Fort Worth International Airport. References to the ICC Electrical Code shall be construed to reference the Electrical Code as adopted herein with its local amendments.

#### SECTION 301.1 CREATION OF ENFORCEMENT AGENCY

Amend Section 301.1 to read as follows:

**301.1 Creation of enforcement agency.** The department of electrical inspection is hereby created and the official in charge thereof shall be known as the ~~code building~~ official. The function of the department shall be to assist the ~~code building~~ official in the administration and enforcement of the provisions of this code. References to the department of electrical inspection shall mean the Code Compliance Section of the Airport Development and Engineering Department.

#### SECTION 404.2 SCHEDULE OF PERMIT FEES

Amend Section 404.2 to read as follows:

**404.2 Schedule of permit fees.** Refer to Part Two, Building Code Amendments, Section 108 for fees.

#### SECTION 501.1 SUBMITTAL DOCUMENTS

Add the following sentence below Section 501.1:

Refer to Part Two, Building Code Amendments, Section 106.1 for additional requirements related to submittal of construction documents.

### **SECTION 1003.1 PENALTIES**

Add the following sentence below Section 1003.1:

Refer to Part One, Construction and Fire Prevention Standards Resolution, Section 27, Penal Clause.

### **CHAPTER 11 MEANS OF APPEAL**

Replace Chapter 11 with the following reference.

Refer to Part One, Construction and Fire Prevention Standards Resolution for Board of Appeals.

### **Local Amendments to NFPA 70 2005 National Electrical Code**

#### **NEC SECTION 230.71(A) MAXIMUM NUMBER OF DISCONNECTS – GENERAL**

Add the following exception below Section 230.71(A) to read as follows:

*Exception: In multi-occupant buildings, individual service disconnecting means is limited to six for each occupant. In this context, the number of individual disconnects at one location may exceed six.*

#### **NEC SECTION 300.11(A) SECURED IN PLACE**

Add the following exception below Section 300.11(A) to read as follows:

*Exception: Ceiling grid support wires may be used for structural supports when the associated wiring is located in that area. No more than two raceways or cables may be supported per support wire, with a maximum nominal metric designation 16 (trade size ½").*

## PART FIVE - MECHANICAL CODE AMENDMENTS

### SECTION 101.1 TITLE

Amend Section 101.1 to read as follows:

**101.1 Title.** The 2006 International Mechanical Code as amended herein is the Mechanical Code of Dallas-Fort Worth International Airport. References to the International Mechanical Code shall be construed to reference the Mechanical Code as adopted herein with its local amendments.

### SECTION 103.1 DEPARTMENT OF MECHANICAL INSPECTION – GENERAL

Amend Section 103.1 as follows:

**103.1 General.** The department of mechanical inspection is hereby created and the executive official in charge thereof shall be known as the ~~code~~ building official. References to the department of mechanical inspection shall mean the Code Compliance Section of the Airport Development and Engineering Department.

### SECTION 106.3.1 CONSTRUCTION DOCUMENTS

Add the following sentence below Section 106.3.1:

Refer to Part Two, Building Code Amendments, Section 106.1 for additional requirements related to submittal of construction documents.

### SECTION 106.5.2 FEE SCHEDULE

Amend Section 106.5.2 to read as follows:

**106.5.2 Fee schedule.** Refer to Part Two, Building Code Amendments, Section 108 for fees.

**SECTION 106.5.3  
FEE REFUNDS**

Amend Section 106.5.3 to read as follows:

**106.5.3 Fee refunds.** The building official is authorized to establish a refund policy.

**SECTION 108.4  
VIOLATION PENALTIES**

Amend Section 108.4 to read as follows:

**108.4 Violation penalties.** Refer to Part One, Construction and Fire Prevention Standards Resolution, Section 27, Penal Clause.

**SECTION 109  
MEANS OF APPEAL**

Replace Section 109 with the following reference:

Refer to Part One, Construction and Fire Prevention Standards Resolution for Board of Appeals.

## PART SIX - PLUMBING CODE AMENDMENTS

### SECTION 101.1 TITLE

Amend Section 101.1 to read as follows:

**101.1 Title.** The 2006 International Plumbing Code as amended herein is the Plumbing Code of Dallas-Fort Worth International Airport. References to the International Plumbing Code shall be construed to reference the Plumbing Code as adopted herein with its local amendments.

### SECTION 103.1 DEPARTMENT OF PLUMBING INSPECTION – GENERAL

Amend Section 103.1 as follows:

**103.1 General.** The department of Plumbing inspection is hereby created and the executive official in charge thereof shall be known as the ~~code~~ building official. References to the department of plumbing inspection shall mean the Code Compliance Section of the Airport Development and Engineering Department.

### SECTION 106.3.1 CONSTRUCTION DOCUMENTS

Add the following sentence below Section 106.3.1:

Refer to Part Two, Building Code Amendments, Section 106.1 for additional requirements related to submittal of construction documents.

### SECTION 106.6.2 FEE SCHEDULE

Amend Section 106.6.2 to read as follows:

**106.6.2 Fee schedule.** Refer to Part Two, Building Code Amendments, Section 108 for fees.

**SECTION 106.6.3  
FEE REFUNDS**

Amend Section 106.6.3 to read as follows:

**106.6.3 Fee refunds.** The building official is authorized to establish a refund policy.

**SECTION 108.4  
VIOLATION PENALTIES**

Amend Section 108.4 to read as follows:

**108.4 Violation penalties.** Refer to Part One, Construction and Fire Prevention Standards Resolution, Section 27, Penal Clause.

**SECTION 109  
MEANS OF APPEAL**

Replace Section 109 with the following reference:

Refer to Part One, Construction and Fire Prevention Standards Resolution for Board of Appeals.

**SECTION 312.9  
INSPECTION AND TESTING OF BACKFLOW PREVENTION ASSEMBLIES**

Replace Section 312.9 with the following reference:

**312.9 Inspection and testing of backflow prevention assemblies.** Backflow prevention assemblies shall be inspected and tested as required by Texas Administrative Code, Title 30, Part 1, Chapter 290 Public Drinking Water.

**TABLE 403.1  
MINIMUM NUMBER OF PLUMBING FACILITIES**

Amend public assembly areas of passenger terminals in Table 403.1 as follows:

OCCUPANCY	WATER CLOSETS (Urinals see Section 419.2)		LAVATORIES	BATHTUBS/ SHOWERS	DRINKING FOUNTAINS (See Section 410.1)	OTHERS
	Male	Female				
Public assembly areas of passenger terminals and transportation facilities	1 per 100	1 per 100	1 per 200	---	1 per 1,000	1 service sink

**SECTION 404  
ACCESSIBLE PLUMBING FACILITIES**

Replace Section 404 as follows:

Refer to Part One, Building Code Amendments, Chapter 11 for accessibility standards.

**SECTION 1106.1  
CONDUCTORS, LEADERS AND STORM DRAINS**

Amend to read as follows:

**1106.1 General.** The size of the vertical conductors and leaders, building storm drains, building storm sewers and any horizontal branches of such drains or sewers shall be based on 5 inches per hour rainfall rate.

**SECTION 1108  
COMBINED SANITARY AND STORM SYSTEM**

Delete Section 1108. Combined sanitary and storm sewer systems shall be prohibited within the airport.

## PART SEVEN - FUEL GAS CODE AMENDMENTS

### SECTION 101.1 TITLE

Amend Section 101.1 to read as follows:

**101.1 Title.** The 2006 International Fuel Gas Code as amended herein is the Fuel Gas Code of Dallas-Fort Worth International Airport. References to the International Fuel Gas Code shall be construed to reference the Fuel Gas Code as adopted herein with its local amendments.

### SECTION 103.1 DEPARTMENT OF INSPECTION – GENERAL

Amend Section 103.1 to read as follows:

**103.1 General.** The Department of Inspection is hereby created and the executive official in charge thereof shall be known as the ~~code building~~ official. References to the department of inspection shall mean the Code Compliance Section of the Airport Development and Engineering Department.

### SECTION 106.3.1 CONSTRUCTION DOCUMENTS

Add the following sentence under Section 106.3.1:

Refer to Part Two, Building Code Amendments, Section 106.1 for additional requirements related to submittal of construction documents.

### SECTION 106.5.2 FEE SCHEDULE

Amend Section 106.5.2 to read as follows:

**106.5.2 Fee schedule.** Refer to Part Two, Building Code Amendments, Section 108 for fees.

**SECTION 106.5.3  
FEE REFUNDS**

Amend Section 106.5.3 to read as follows:

**106.5.3 Fee refunds.** The building official is authorized to establish a refund policy.

**SECTION 108.4  
VIOLATION PENALTIES**

Amend Section 108.4 to read as follows:

**108.4 Violation penalties.** Refer to Part One, Construction and Fire Prevention Standards Resolution, Section 27, Penal Clause.

**SECTION 109  
MEANS OF APPEAL**

Replace Section 109 with the following reference:

Refer to Part One, Construction and Fire Prevention Standards Resolution for Board of Appeals.

## PART EIGHT - ENERGY CODE AMENDMENTS

### SECTION 101.1 TITLE

Amend Section 101.1 to read as follows:

**101.1 Title.** The 2006 International Energy Conservation Code as amended herein is the Energy Code of Dallas-Fort Worth International Airport. References to the International Energy Conservation Code shall be construed to reference the Energy Code as adopted herein with its local amendments.

### SECTION 101.1.1 DEPARTMENT OF INSPECTION – GENERAL

Add Section 101.1.1 as follows:

**101.1.1 General.** The Department of Inspection is hereby created and the executive official in charge thereof shall be known as the building official. References to the department of inspection shall mean the Code Compliance Section of the Airport Development and Engineering Department.

### SECTION 101.2 SCOPE

Amend Section 101.2 to read as follows:

**101.2 Scope.** This code applies to ~~residential and~~ commercial buildings.

### SECTION 101.4.5 MIXED OCCUPANCY

Amend Section 101.4.5 to read as follows:

**101.4.5 Mixed occupancy.** Where a building includes both residential and commercial occupancies, each occupancy shall be separately considered. ~~and meet the applicable provisions of Chapter 4 for residential and Chapter 5 for commercial.~~

### SECTION 101.5 COMPLIANCE

Amend Section 101.5 to read as follows:

**101.5 Compliance.** Residential buildings shall meet the provisions of ~~Chapter 4~~ **Texas Building Energy Performance Standards**. Commercial buildings shall meet the provisions of Chapter 5.

### **SECTION 104.1 CONSTRUCTION DOCUMENTS - GENERAL**

Add the following sentence after the first paragraph under Section 104.1:

Refer to Part Two, Building Code Amendments, Section 106.1 for additional requirements related to submittal of construction documents.

### **SECTION 108 FEE SCHEDULE**

Add Section 108 to read as follows:

**108 Fee schedule.** Refer to Part Two, Building Code Amendments, Section 108 for fees.

### **SECTION 109 FEE REFUNDS**

Add Section 109 to read as follows:

**109 Fee refunds.** The building official is authorized to establish a refund policy.

### **SECTION 110 VIOLATION PENALTIES**

Add Section 110 as follows:

**110 Violation penalties.** Refer to Part One, Construction and Fire Prevention Standards Resolution, Section 27, Penal Clause.

### **SECTION 111 MEANS OF APPEAL**

Add Section 111 as follows:

**111 Means of Appeal.** Refer to Part One, Construction and Fire Prevention Standards Resolution for Board of Appeals.

## CHAPTER 2 DEFINITIONS

Amend definition of code official as follows:

**CODE OFFICIAL.** The building official is charged with the administration and enforcement of this code.

## CHAPTER 4 RESIDENTIAL ENERGY EFFICIENCY

Delete Chapter 4 in its entirety. For residential energy efficiency requirements, refer to Texas Building Energy Performance Standards.

### SECTION 501.3 COMPLIANCE SOFTWARE TOOLS

Add Section 501.3 as follows:

**501.3 Compliance software tools.** Software tools used to demonstrate compliance with the Energy Code will be deemed acceptable to the building official if they utilize either this code or the 2004 Edition of ASHRAE 90.1 - Energy Standard for Buildings Except Low Rise Residential Buildings.

### SECTION 505.2.1 INTERIOR LIGHTING CONTROLS

Amend Section 505.2.1 to read as follows with the exceptions to remain unchanged:

**505.2.1 Interior lighting controls.** Each area enclosed by walls or floor-to-ceiling partitions shall have at least one manual control for the lighting serving that area. The required controls shall be located within the area served by the controls or be a remote switch that identifies the lights served and their status. Each control device shall control a maximum of 2,500 square feet (232.26 square meters) of floor area for a space 10,000 square feet (929.03 square meters) or less and a maximum of 10,000 square feet (929.03 square meters) for a space greater than 10,000 square feet (929.03 square meters).

## **PART NINE – OIL AND GAS EXPLORATION AND PRODUCTION**

### **SECTION 1 GENERAL INFORMATION**

The Exploration, development and Production of Gas on the Airport property are activities which make necessary regulations to establish uniform limitations, safeguards and requirements for operations related to the Exploration, Drilling, developing, producing, transporting and storing of Gas and other substances produced in association with Gas within the Airport to protect the health, safety and general welfare of the public, minimize the potential impact to property, protect the quality of the environment and encourage the orderly production of available mineral, and gas resources.

### **SECTION 2 DEFINITIONS**

The following words, terms and phrases, when used in this Part, shall have the meanings ascribed to them in this section:

*Abandonment:* means “abandonment” as defined by the Commission and includes the plugging of a Well and the restoration of the area used during the Production of a Well as required by this Part.

*All-Weather Hard Surface:* means a permanent surface that as a minimum is a base course constructed such that it meets the requirements of the Fire Code, is at least twenty two feet (22') wide, has an overhead clearance of fourteen feet (14'), drains appropriately, remains water resistant, is free of litter, debris, weeds, grass or other objectionable materials or objects and is visibly dust free.

*API:* means the American Petroleum Institute.

*Berm:* means a mound of soil, either natural or man made, used to obstruct a view. The side slope shall not exceed a three-foot (3') horizontal and a one-foot (1') vertical slope.

*Blowout Preventer:* means a mechanical, hydraulic, pneumatic or other device or combination of such devices, including valves, fittings and control mechanisms connected therewith, which can be closed around the drill pipe, or other tubular goods which completely close the top of the casing and are designed for preventing blowouts.

*Brackish Water:* means flow back water used in the fracturing and re-fracturing process and other waste liquids produced in association with the production, treatment, processing or transportation of hydrocarbons.

*Building:* means any structure used or intended for supporting or sheltering any use or occupancy. Buildings with an occupant load of 3 or fewer in accordance with Table 1004.1.1 of the Building Code are not subject to the setback requirements of this Part.

*Building Code:* as defined in Part Two.

*Building Official:* as defined in Section 5, Part 1.

*Closed Loop System:* means a system utilized while Drilling so that reserve pits are not used and instead steel bins are used to collect all drilling waste.

*Commission:* means the Texas Railroad Commission and all state rules.

*Completion:* means the earlier of the date the work is completed for the Drilling, re-drilling or reworking of a Well and the crew involved in such activities is released or the date the rig is released.

*Derrick:* means any portable framework, tower, mast and/or structure, which is required or used in connection with Drilling or re-working a Well for the production of Gas.

*Disposal Well:* means a well drilled for the purpose of disposing of Brackish Water.

*Drilling:* means digging or boring a new Well for the purpose of exploring for, developing or producing Gas or for the purpose of injecting Gas, water or any other fluid or substance into the earth.

*Drill Site:* means the immediate area used during the Drilling, re-drilling or re-working of a Well.

*Electrical Code:* as defined in Part Four.

*Emergency Response Plan:* means a plan put in place to deal with emergency situations that may occur at the Drill Site and/or the Operation Site.

*Energy Code:* as defined in Part Eight.

*Exploration:* means geologic or geophysical activities, including seismic surveys, related to the search for Gas or other subsurface hydrocarbons.

*FEMA:* means the Federal Emergency Management Agency.

*FIRM:* means the Flood Insurance Rate Map.

*Fire Chief:* as defined in Section 5, Part 1

*Fire Code:* as defined in Part Three.

*Fire Department:* means the Fire Department of the Airport.

*Frac Tank:* means an enclosed steel tank used to hold Brackish Water.

*Fracturing:* means the injecting of a substance into a Well or formation so as to cause underground channels in hydro-carbon-bearing formations to open.

*Fresh Water Fracing Pit:* means a pond, open to the atmosphere, used to hold fresh water for Fracturing.

*Fuel Gas Code:* as defined in Part Seven.

*Gas:* means any fluid, either combustible or noncombustible, which is produced in a natural state from the earth and which maintains a gaseous or rarefied state at standard temperature and pressure conditions and/or the gaseous components or vapors occurring in or derived from petroleum or Gas.

*Gas Well:* means any Well drilled, to be drilled, or used for the intended or actual production of natural gas.

*Mechanical Code:* as defined in Part Five.

*Oil:* means crude petroleum oil and other hydrocarbons regardless of gravity which are produced at the wellhead in liquid form and the liquid hydrocarbons known as distillate or condensate recovered or extracted from Gas, other than gas produced in association with oil and commonly known as casinghead gas.

*Oil Well:* means any Well drilled, to be drilled, or used for the intended or actual production of Oil.

*Operation Site:* means the area used for development and production and all operational activities associated with Gas after Drilling activities are complete.

*Operator:* means, for each Well, the person listed on the Commission's Form W-1 or Form P-4 for a Gas Well or Oil Well that is, or will be actually in charge and in control of Drilling, maintaining, operating, pumping or controlling any Well, including, without limitation, a unit operator.

*Permit:* means any written license granted by the Airport authorizing the Operator to undertake activity on the Airport.

*Plumbing Code:* as defined in Part Six.

*Production:* means the period between Completion of Drilling and the Abandonment of the Well.

*Re-Drill:* means the Drilling of a new Well located in essentially the same place as an earlier Well or the re-completion of an existing Well by deepening or sidetrack operations extending more than one hundred fifty feet (150') from the existing Well bore.

*Re-working:* means re-completion or re-entry of an existing Well within the existing bore hole or by deepening or sidetrack operations which do not extend more than one hundred fifty feet (150') from the existing well bore, or replacement of well liners or casings.

*Street:* means any street, highway, sidewalk, alley, or avenue that is open to public use or is in support of Airport operations.

*SWPPP:* means stormwater pollution prevention plan.

*TCEQ:* means the Texas Commission on Environmental Quality.

*USEPA:* means the United States Environmental Protection Agency.

*Well:* means any single hole or bore to any horizon, formation, or strata, for the purpose of producing Gas and/or Oil from the Airport.

### **SECTION 3 AIRPORT OVERSIGHT**

The Building Official is charged with the administration and enforcement of this part. The Building Official and the Fire Chief shall have the authority to enter and inspect any Drill Site or Operation Site to determine compliance with this Resolution and all applicable laws, rules, regulations, standards or directives adopted by the Airport Board or State. Failure of any person to permit access to the Building Official or Fire Chief shall constitute a violation of this Resolution. Additionally, the Building Official or Fire Chief and other Airport officials shall have the authority to issue any orders or directives required to implement the intent and purpose of this Resolution and its provisions. The Building Official or Fire Chief shall have the authority to request and receive any records, including any records sent to the Commission, logs, reports and the like, relating to the status or condition of any Well necessary to establish and determine compliance with a Permit. Failure of any person to provide any such requested material shall be deemed a violation of this Resolution.

## **SECTION 4 OPERATOR'S AGENT**

Every Operator shall designate an agent, who is a resident of the State of Texas, upon whom all orders and notices provided in this Resolution may be served in person or by registered or certified mail. Every Operator designating such agent shall within ten (10) days notify the Building Official in writing of any change in such agent or such mailing address unless operations within the Airport are discontinued. Failure to do so shall be deemed a violation of this Resolution.

## **SECTION 5 SEISMIC SURVEY PERMIT REQUIREMENTS**

A Permit shall be required for all geophysical tests, including but not limited to seismic surveys. All applications for a Permit to conduct geophysical tests, including but not limited to seismic surveys, shall be submitted to the Building Official for approval. No geophysical tests shall begin prior to the issuance of a Permit from the Airport Board. A Permit application shall include, but is not limited to, the following information:

- (a) Operator/applicant name, phone number, fax number, physical address, and e-mail address.
- (b) Detailed mapping of location and extent of the proposed geophysical test.
- (c) Detailed explanation of the survey or testing method to be used.
- (d) Frequency and strength of all radio frequency (RF) signals.
- (e) Under no circumstances may explosive charges, including, but not limited to, the use of dynamite, be used in any way related to the preparation for and/or conducting of a geophysical test.

## **SECTION 6 GAS WELL AND DISPOSAL WELL PERMIT REQUIREMENTS**

- (a) No person acting either for himself or acting as an agent, employee, independent contractor, or servant of any person shall drill any Well or Disposal Well, assist in any way in the site preparation, re-working, Fracturing or operation of any Well or Disposal Well or to conduct any activity related to the production of Gas without first obtaining a Permit issued by the Building Official in accordance with this Resolution. Such activities include, but are not limited to, initial site preparation, re-working, Drilling, operations, construction of rigs, Fresh Water Fracing Pit or tank batteries, Fracturing and pressurizing.

- (b) The Operator must apply for and obtain a Permit for the Drilling of each Well or Disposal Well. The Operator shall neither apply for nor obtain a “blanket” Permit for more than one (1) Well. A Disposal Well permit will only be issued for disposal of Brackish Water from oil and gas exploration and production, treatment or transportation of hydrocarbons within the boundaries of Dallas/Fort Worth International Airport property. All Disposal Wells must deposit Brackish Water into the Ellenberger formation. Each new Well or Disposal Well established at the ground surface will be considered a new Well or Disposal Well as applicable.
- (c) An existing Permit shall not constitute authority for the re-entering and Drilling of a Well the subject of Abandonment. An Operator shall obtain a new Permit in accordance with the provisions of this Resolution if the Operator is re-entering and Drilling an abandoned Well.
- (d) When a Permit has been issued to the Operator for the Drilling, re-entering, activating or converting of a Well, such Permit shall constitute sufficient authority for Drilling, operation, production gathering or production maintenance, repair, re-working, testing, plugging and Abandonment of the Well and/or any other activity associated with mineral exploration at an Operation Site. An amended Permit shall be obtained before such Well may be modified for purposes of re-drilling, deepening or converting such Well to a depth or use other than that set forth in the then-current Permit for such Well.
- (e) Any person who intends to re-work a Well using a Drilling rig or to engage in Fracturing a Well after initial Completion shall give written notice to, and receive written approval from, the Building Official. The notice must identify where the activities will be conducted and must describe the activities in detail, including, but not limited to the duration of the activities and the time the activities will be conducted. The notice must also provide the address and twenty-four (24) hour telephone number of the person conducting the activities.
- (f) A Permit shall automatically terminate, unless extended, if Drilling is not commenced within one year from the date of the issuance of the Permit. A Permit may be extended by the Building Official upon written request by the Operator and proof that the regulatory standards of the requested Permit for such location have not changed.
- (g) Permits required by this Resolution are in addition to and are not in lieu of any permit, which may be required by any other governmental agency.
- (h) No Permit shall be issued for any Well to be drilled within the floodway identified by FEMA on the most current FIRM. Wells proposed in the floodplain outside of the floodway shall comply with the requirements of the Building Official.

- (i) No Permit shall be issued for any Well to be drilled that is not in compliance with this Resolution.
- (j) By acceptance of any Permit issued pursuant to this Resolution, the Operator expressly stipulates and agrees to be bound by and comply with the provisions of this Resolution. The terms of this Resolution shall be deemed to be incorporated in any Permit issued pursuant to this Resolution with the same force and effect as if this Resolution was set forth verbatim in such Permit.
- (k) Operator must provide to the Building Official, a copy of all H-5 and mechanical integrity tests required by the Commission.

## **SECTION 7 PERMIT APPLICATION**

- (a) Every application for a Permit issued pursuant to this Resolution shall be on forms required by the Building Official, shall include payment of the construction permit and plan review fees and shall be signed by the Operator, or some person duly authorized to sign on his behalf, and filed with the Building Official. The application shall include the following information:
  - (1) The date of the application and type of Permit requested.
  - (2) Map showing proposed transportation route and road(s) for equipment, chemicals or waste products used or produced under the Permit.
  - (3) Proposed Well name and Well depth.
  - (4) Name, telephone number, fax number, physical address of individual designated to receive notice, and, if possible, e-mail address.
  - (5) Names and addresses of representatives or Operator's agent with supervisory authority over the Drill Site or Operation Site and a twenty-four (24) hour telephone number.
  - (6) Location and description of all improvements and structures within eight hundred feet (800') of the Well. Such locations and descriptions shall be prepared by a Registered Professional Land Surveyor.
  - (7) A site plan of the proposed Drill Site and Operation Site showing the location of all improvements and equipment, including the location of the proposed Well and other facilities including, but not limited to, Fresh Water Fracing Pit, Disposal Well, tanks, pipelines, compressors, separators and storage tanks or storage sheds. All site plans must include the following criteria:

- a. Location of proposed Buildings and structures indicating sizes in square feet.
  - b. The location and intensity of exterior lighting fixtures.
  - c. The location of mechanical equipment.
  - d. Outside storage areas.
  - e. Curb cut locations.
  - f. Parking, loading, and maneuvering areas.
  - g. The location, materials and dimensions of screening improvements as required.
  - h. Waste disposal locations.
  - i. Streets immediately adjacent to the Operation Site.
  - j. Drill Site and Operation Site plans shall be submitted on a sheet size of 24" x 36" minimum, or as approved by the Building Official, or as approved by the Building Official.
  - k. Airport boundaries where applicable.
  - l. Date the drawing was prepared with name, address, and phone number of preparer.
  - m. North arrow, at a maximum scale of 1:50 immediately adjacent to the Drill Site or Operation Site.
  - n. Title Block identifying the Drill Site or Operation Site location.
  - o. Vicinity location map at 1" = 2000'.
  - p. Location of 100-year flood limits where applicable.
  - q. Texas NAD83 State Plane Coordinates for all four corners.
- (8) Copy of all reports and permits required by the Commission, specifically including a copy of the approved Commission Form W-1, H-5 and/or P-4.
- (9) A description of public utilities required during Drilling and Production.

- (10) A description of the water source to be used during Drilling.
- (11) A copy of the Erosion Control Plan as required by the Airport Board.
- (12) A copy of the determination by the TCEQ of the depth of useable quality ground water.
- (13) A copy of the TCEQ permit.
- (14) A statement, under oath, signed by the Operator or designated representative, that the information submitted with the application is, to the best knowledge and belief of the Operator or designated representative, true and correct.
- (15) Three copies of a Hazardous Material Management Plan and additionally, all material safety data sheets for all hazardous materials that will be located, stored, transported and/or temporarily used on the Drill Site shall be provided to the Building Official.
- (16) Three copies of the Hazardous Materials Inventory Statement.
- (17) Operator shall submit to the Building Official, for review and approval, an Emergency Response Plan establishing written procedures to minimize any hazard resulting from Drilling, Completion or producing of a Gas Well. Said plan shall use existing guidelines established by the Commission, TCEQ, Texas Department of Transportation, the Fire Code and/or the USEPA. A copy of the Emergency Response Plan shall be kept on site.
- (18) A map showing the location of all underground transmission pipelines.

## **SECTION 8 PERMITTING PROCEDURE**

- (a) All Well Permit applications will be filed through the Building Official.
- (b) It is the responsibility of the Building Official to review and approve or disapprove all applications for Permits based on the criteria established by this Resolution.
- (c) After the filing of a completed application, payment of permit and plan review fees and remittance of all insurance and security per the requirements of this Resolution for a Permit, the Building Official will determine whether the Permit application shall be approved or denied.
- (d) The provisions of this Resolution shall apply to any application for a Permit that is filed with the Building Official.

- (e) If all the requirements of this Resolution are met, the Building Official shall issue a Permit for the activity for which the Permit application was made.
- (f) If the Building Official denies a Permit application, the Building Official shall notify the Operator in writing of such denial stating the reasons for the denial. The Operator may cure those conditions that caused the denial and resubmit the application to the Building Official for approval and issuance of the Permit.

**SECTION 9  
AMENDED GAS WELL PERMITS**

- (a) An amended Permit may be issued for, but not limited to, the following changes in Drill Site or Operation Site activities:
  - (1) Re-drilling;
  - (2) Deepening beyond one hundred fifty feet (150') of the permitted depth;
  - (3) Site access; and
  - (4) Locations and/or quantities of equipment as determined by the Building Official;
- (b) Applications for amended Permits shall be in writing, shall be signed by the Operator, and shall include the following:
  - (1) A description of the proposed amendments;
  - (2) Any changes to the information submitted with the application for the existing Permit (if such information has not previously been provided to the Airport Board);
  - (3) Such additional information as is reasonably required by the Building Official to demonstrate compliance with the Permit;
  - (4) Such additional information as is reasonably required by the Building Official to prevent imminent destruction of property or injury to persons; and
  - (5) An amended site plan.
- (c) All applications for amended Permits shall be filed with the Building Official for review. Incomplete applications may be returned to the applicant, in which case the Building Official shall provide a written explanation of the deficiencies.

- (d) If the activities proposed by the amendment are not materially different from the activities covered by the existing Permit then the Building Official shall approve or disapprove the amendment after the application is filed.
- (e) If the activities proposed by the amendment are materially different from the activities covered by the existing Permit, and do not create a risk of destruction of property or injury to persons, then the Building Official shall approve or disapprove the amendment. If, however, the activities proposed by the amendment are materially different and, in the judgment of the Building Official might create a risk of destruction of property or injury to persons that were not associated with the activities covered by the existing Permit or that were not otherwise taken into consideration by the existing Permit, the Building Official may require the amendment to be processed as a new Permit application.

## **SECTION 10 SUSPENSION OR REVOCATION OF WELL PERMITS**

- (a) If an Operator (or its officers, employees, agents, contractors, or representatives) fails to comply with any requirement of a Permit (including any requirement incorporated by reference as part of the Permit), the Airport Board shall give written notice to the Operator specifying the nature of the failure and giving the Operator a reasonable time to cure, taking into consideration the nature and extent of the failure, the extent of the efforts required to cure, and the potential impact on the health, safety, and welfare of the public. In no event, however, shall the cure period be less than ten (10) days unless the failure presents a risk of imminent danger to property or injury to persons or unless the failure involves the Operator's failure to provide periodic reports as required by this Resolution.
- (b) If the Operator fails to correct the noncompliance, the Airport Board may suspend or revoke the Permit pursuant to the provisions of this Resolution.
- (c) No person shall carry on any operations performed under the terms of a Permit issued under this Resolution during any period of any suspension or revocation of the Permit or pending a review of the decision or order of the Airport Board in suspending or revoking the Permit. Nothing contained herein shall be construed to prevent the necessary, diligent and bona fide efforts to cure and remedy the default or violation for which the suspension or revocation of the Permit was ordered for the safety of persons or as required by the Building Official or the Fire Chief.
- (d) If the Operator does not cure the noncompliance within the time specified in this Resolution, the Airport Board, upon written notice to the Operator, may notify the Commission and request that the Commission take any appropriate action.

## **SECTION 11 PERIODIC REPORTS**

- (a) The Operator shall notify the Building Official of any changes to the following information within ten (10) days after the change occurs:
- (1) The name, physical address, telephone number, and fax number of the Operator;
  - (2) The name, address, and telephone number of the person designated to receive notices from the Airport Board (which person must be a resident of Texas that can be served in person or by registered or certified mail); and
  - (3) The Operator's emergency action response plan (including "drive-to-maps" from rights-of-way to each Drill Site or Operation Site).
- (b) The Operator shall notify in writing the Building Official of any change to the name, address, and twenty-four (24) hour phone number of the person(s) with supervisory authority over Drilling or operations activities within one (1) business day.
- (c) The Operator shall provide a copy of any "incident reports" or written complaints submitted to the Commission and a copy to the Airport Board within thirty (30) days after the Operator has notice of the existence of such reports or complaints.
- (d) Beginning on December 31<sup>st</sup> after each Well is completed, and continuing on each December 31<sup>st</sup> thereafter until the Operator notifies the Building Official that there has been an Abandonment of the Well and the Operation Site is restored, the Operator shall submit a written report to the Building Official identifying any changes to the information that was included in the application for the applicable Permit that have not been previously reported to the Building Official.

## **SECTION 12 BOND, LETTERS OF CREDIT, INDEMNITY INSURANCE**

- (a) *General requirements.* The Operator shall be required to:
- (1) Comply with the terms and conditions of this Resolution and the Permit issued hereunder.
  - (2) Promptly clear each Drill Site and Operation Site of all litter, trash, waste and other substances used, allowed, or occurring in the operations, and after Abandonment or Completion grade, level and restore such property to the same surface conditions as nearly as possible as existed before operations as determined by the Building Official.

- (3) Promptly pay all fines, penalties and other assessments imposed due to breach of any terms of the Permit.
  - (4) Promptly restore to its former condition any property damaged by the Operator.
- (b) *Bond, irrevocable letter of credit.* Prior to the issuance of a Permit the Operator shall provide the Building Official with a security instrument in the form of a bond or an irrevocable letter of credit as follows:
- (1) **Bond.** A bond shall be executed by a reliable bonding or insurance institution authorized to do business in Texas, acceptable to the Airport Board. The bond shall become effective on or before the date the Permit is issued and shall remain in force and effect for at least a period of six (6) months after the expiration of the Permit term or until there has been an Abandonment of the Well and the Operation Site is restored, whichever occurs last. The Operator shall be listed as principal and the instrument shall run to the Airport Board, as obligee, and shall be conditioned that the Operator will comply with the terms and regulations of this Resolution and all other laws and regulations. The original bond shall be submitted to the Building Official.
  - (2) **Letter of Credit.** A letter of credit shall be issued by a reliable bank authorized to do business in Texas and shall become effective on or before the date the Permit is issued. The letter of credit shall remain in force and effect for at least a period of six (6) months after the expiration of the Permit term or until there has been an Abandonment of the Well and the Drill Site or Operation Site is restored, whichever occurs last. The Airport Board shall be authorized to draw upon such letter of credit to recover any fines, penalties or costs to remedy assessed under this Resolution. Evidence of the execution of a letter of credit shall be submitted to the Building Official by submitting an original signed letter of credit from the banking institution.
  - (3) The principal amount of any security instrument shall be fifty thousand dollars (\$50,000) for any single Well. After Completion of a Well, the Operator may submit a request to the Building Official to reduce the existing bond to ten thousand dollars (\$10,000) for the remainder of the time the Well produces without reworking. During reworking operations, the amount of the bond or letter of credit shall be maintained at fifty thousand dollars (\$50,000). If at any time after no less than a fifteen (15) day written notice to the Operator, the Airport Board shall deem any Operator's bond or letter of credit to be insufficient, it may require the Operator to increase the amount of the bond or letter of credit up to a maximum of two hundred fifty thousand dollars (\$250,000) per Well.

- (4) Whenever the Building Official finds that a default has occurred in the performance of any requirement or condition imposed by this Resolution, a written notice shall be given to the Operator. Such notice shall specify the work to be done, the estimated cost and the period of time deemed by the Building Official to be reasonably necessary for the completion of such work. After receipt of such notice, the Operator shall, within the time therein specified, either cause or require the work to be performed, or failing to do so, shall pay over to the Airport Board one hundred twenty-five percent (125%) of the estimated cost of doing the work as set forth in the notice. In no event, however, shall the cure period be less than thirty (30) days unless the failure presents a risk of imminent destruction of property or injury to persons or unless the failure involves the Operator's failure to provide periodic reports as required by this Resolution. The Airport Board shall be authorized to draw against any irrevocable letter of credit or bond to recover such amount due from the Operator. Upon receipt of such monies, the Airport Board shall proceed by such mode as deemed convenient to cause the required work to be performed and completed, but no liability shall be incurred other than for the expenditure of said sum in hand. In the event there has not been a proper Abandonment of the Well under the regulations of the Commission, such additional money may be demanded from the Operator as is necessary to properly plug and abandon the Well and restore the Drill Site or Operation Site in conformity with the regulations of this Resolution.
  - (5) In the event the Operator does not cause the work to be performed and fails or refuses to pay over to the Airport Board the estimated cost of the work to be done as set forth in the notice, or the issuer of the security instrument refuses to honor any draft by the Airport Board against the applicable irrevocable letter of credit or bond, the Airport Board may proceed to obtain compliance and abate the default by way of civil action against the Operator, or by criminal action against the Operator, or by both such methods.
  - (6) When there has been a proper Abandonment of the Well or Wells covered by said irrevocable letters of credit or bond in conformity with all regulations of this Resolution, and in conformity with all regulations of the Commission and notice to that effect has been received by the Airport Board, or upon receipt of a satisfactory substitute, the irrevocable letter of credit or bond issued in compliance with these regulations shall be terminated and cancelled.
- (c) *Insurance.* The Operator must at all times maintain the specific coverages listed below.
- (1) Environmental pollution liability coverage. Operator shall purchase and maintain in force for the duration of the Permit, insurance for environmental

pollution liability applicable to bodily injury; property damage, including loss of use of damaged property or of property that has not been physically injured or destroyed; cleanup costs; and defense, including costs and expenses incurred in the investigation, defense or settlement of claims; all in connection with any loss arising from the insured site. Coverage shall be maintained in an amount of at least one million dollars (\$1,000,000) per loss, with an annual aggregate of at least ten million dollars (\$10,000,000).

- a. Coverage shall apply to sudden and accidental pollution conditions resulting from the escape or release of smoke, vapors, fumes, acids, alkalis, toxic chemicals, liquids or gases, waste material or other irritants, contaminants or pollutants.
  - b. The Operator shall maintain continuous coverage and shall purchase extended coverage period insurance when necessary. The extended coverage period insurance must provide that any retroactive date applicable to coverage under the policy precedes the effective date of the issuance of the Permit by the Building Official.
- (2) Control of Well. The policy should cover the cost of controlling a Well that is out of control, re-drilling or restoration expenses, seepage and pollution damage as first party recovery for the Operator and related expenses, including, but not limited to, loss of equipment, experts and evacuation of residents, in the amount of five million dollars (\$5,000,000) per occurrence/no aggregate, if available, otherwise an aggregate of ten million dollars (\$10,000,000). Five hundred thousand dollars (\$500,000) sub-limit endorsement may be added for damage to property for which the Operator has care, custody and control.

### **SECTION 13 SETBACK REQUIREMENTS**

The following are minimum setbacks.

- (a) It shall be unlawful to drill, re-drill, deepen, re-enter, activate or convert any Well or Disposal Well, the center of which, at the surface of the ground, is located:
  - (1) Within six hundred feet (600') from any Building; or
  - (2) Within one hundred feet (100') from any Building accessory to, but not necessary to the operation of the well; or
  - (3) Within seventy-five feet (75') of any existing or planned right of way for street, highway or rail; or
  - (4) Within two hundred feet (200') of any existing potable water well.

- (b) Tank batteries, separators and compressors and their associated vents and flares shall be located at least three hundred feet (300') from any Street or Building not used in operations on the Drill Site or Operations Site, nor less than five hundred feet (500') from any flammable bulk storage facility.
- (c) Fresh Water Fracing Pits shall be located at least one hundred feet (100') from any Street or Building.
- (d) The measurement of all distances shall be calculated from the proposed Well bore, Disposal Well bore, tank battery, separator, compressor or Fresh Water Fracing Pit in a straight line, without regard to intervening structures or objects to the closest exterior point of the object listed in items (a) through (c) above. The above calculations shall be prepared by a Registered Professional Land Surveyor.
- (e) As to any public park, residence, religious institution, hospital building, school or other public building that is outside the boundaries of the Airport, the distances set out in subsections (a) through (c) of this section may not be reduced without both of the following:
  - (1) Written notarized waivers granted by all the surface owners must be filed, at the expense of the Operator, in the applicable county records. All waivers must identify the property address, block and lot number, subdivision name and plat volume and page number.
  - (2) With an approved variance obtained in accordance with procedures outlined under Section 20 of this Part.
- (f) As to any Building that is within the boundaries of the Airport, the distances set out in subsections (a) through (c) of this section may be reduced with an approved variance in accordance with procedures outlined under Section 20 of this Part but may not be reduced to less than that permitted by the Fire Code.

#### **SECTION 14 ON SITE AND TECHNICAL REGULATIONS**

- (a) Abandoned Wells. All Wells shall be abandoned in accordance with the rules of the Commission; however, all Well casings shall be cut and removed to a depth of at least three feet (3') below the surface unless the Airport Board agrees in writing otherwise. No Building shall be built over an abandoned Well. A well marker, with the well number displayed on it, must be welded to the top of the cut off well pipe.
- (b) Blowout prevention. In all cases, blowout prevention equipment shall be used on all wells being drilled, worked-over or in which tubing is being changed.

Protection shall be provided to prevent blowout during petroleum or gas operations as required by and in conformance with the requirements of the Commission and the recommendations of the American Petroleum Institute. The Operator must equip all Drilling Wells with adequate blowout preventers, flow lines and valves commensurate with the working pressures involved as required by the Commission.

The ram-type blowout preventers, valves, and manifolds shall be pressure tested as follows:

- 1.) at the time of installation,
- 2.) whenever any seal subject to test pressure is broken,
- 3.) following related repairs and
- 4.) at 30 day intervals thereafter.

A period of more than thirty (30) days between blowout preventer tests may be allowed, with the Building Official's approval, when well operations prevent testing, provided the tests will be conducted as soon as possible before normal operations resume. The record of communications with the Building Official shall be entered in the driller's log.

During drilling and completion operations, the ram-type blowout preventers shall be tested by closing at least once each trip, and the annular-type preventer shall be tested by closing on drill pipe once each week. All of the above described tests and/or drills shall be recorded in the drilling log and made available to the Building Official upon request.

- (c) Hazardous materials storage. All chemicals and/or hazardous materials shall be stored in such a manner as to prevent, contain, and facilitate rapid remediation and cleanup of any accidental spill, leak, or discharge of a hazardous material. Operator shall have all material safety data sheets for all hazardous materials on site. All applicable federal and state regulatory requirements for the proper labeling of containers shall be followed. All hazardous materials and/or special hazards at the Well sites shall be protected in accordance with National Fire Protection Association standards, and the Fire Code. Appropriate pollution prevention actions shall be required and include, but are not limited to, chemical and materials raised from the ground (e.g., wooden pallets), bulk storage, installation and maintenance of secondary containment systems, and protection from storm water and weather elements.
- (d) The following requirements shall apply to all Fracturing operations performed on a Well:
  - (1) A watchperson shall be required at all times during such operations; and

- (2) At no time shall the Well be allowed to flow or vent directly to the atmosphere without first directing the flow through separation equipment or into a portable tank.
- (e) Compliance. Operator shall comply at all times with all applicable federal, state and Airport Board requirements. In the event of any conflicts between the provisions of this Resolution, and the Commission rules and regulations, the more restrictive provision shall apply. Whenever necessary to protect health, safety or welfare, the Building Official or the Fire Chief may direct any Operator to locate, relocate, remove or replace any Well surface facilities located within a particular Operation Site.
- (f) Discharge. No person shall place, deposit, discharge, or cause or permit to be placed, deposited or discharged, any oil, naphtha, petroleum, asphalt, tar, hydrocarbon substances or any refuse including wastewater or brine from any gas operation or the contents of any container used in connection with any gas operation in, into, or upon any Streets, lots, storm drain, ditch or sewer, sanitary drain or any body of water or any property of the Airport.
- (g) Drill stem testing. All open hole formation or drill stem testing shall be done during daylight hours, with adequate advance notification thereof to the Building Official to enable him to be present during such testing. Drill stem tests may be conducted only if the Well effluent during the test is produced through an adequate gas separator to storage tanks and the effluent remaining in the drill pipe at the time the tool is closed is flushed to the surface by circulating drilling fluid down the annulus and up the drill pipe.
- (h) Drip pans and other containment devices. All materials on location (liquids, semi-liquids and solids) and any tanks, containers, pumps, lubricating systems, engines, fuel and chemical storage tanks or systems containing such materials shall be provided with drips pans or other containment devices appropriate to the risks and hazards that those materials pose to workers, the public and the environment.
- (i) Dust, vibration, odors. All Drilling and production operations shall be conducted in such a manner as to minimize, so far as practicable, dust, vibration, or noxious odors, and shall be in accordance with the best accepted practices incident to Drilling for the production of Gas and other hydrocarbon substances. All equipment used shall be so constructed and operated so that, vibrations, dust, odor or other harmful or annoying substances or effect will be minimized by the operations carried on at any Drilling or production site or from anything incident thereto; nor shall the site or structures thereon be permitted to become dilapidated, unsightly or unsafe. Proven technological improvements as identified by the Building Official in industry standards of Drilling and production in this area may be adopted as they become available if capable of reducing dust, vibration and odor.

- (j) Electric lines. All electric lines to production facilities shall be located in a manner compatible to those already installed in the surrounding area.
- (k) Emergency Response Plan. Prior to the commencement of any Gas or other hydrocarbons site activities, Operator shall submit to the Building Official an Emergency Response Plan establishing written procedures to minimize any hazard resulting from Drilling, Completion or producing of a Gas Well. Said plan shall use existing guidelines established by the Commission, TCEQ, Texas Department of Transportation and/or the USEPA. The Emergency Response Plan shall be kept current with any additions, modifications, and/or amendments concerning all construction-related activities, natural gas operations and, and/or natural gas production. Those updates to the Plan which might materially impact the needs or actions of first responders or the DFW Airport Emergency Management Plan shall be submitted to the approved distribution list as soon as practical. A copy of the Emergency Response Plan shall be kept on site.
- (l) Explosives. Use of explosives within Airport property shall require an Operational Permit issued by the DFW Department of Public Safety Fire Prevention Office. Each use of explosives will be limited to a single period of time, individual locations and use for jet perforation of wells or other technical applications such as pipe recovery, as described to, and approved by, the DFW DPS Fire Prevention Office prior to use.
- (m) Fire prevention; sources of ignition. Firefighting apparatus and supplies as approved by the Fire Department and required by any applicable federal, state, local law, or the Fire Code shall be provided by the Operator, at the Operator's cost, and shall be maintained on the Drill Site at all times. The Operator shall be responsible for the maintenance and upkeep of such equipment. At a minimum, the Operator shall provide at each Drill Site at least four portable fire extinguishers, the size, rating, distribution and maintenance of which shall be in accordance with the National Fire Protection Association Standard #10 and Standard #30. The Fire Department may require more fire extinguishers based on an evaluation of the hazards at the individual sites. Each Well shall be equipped with an automated valve that closes the Well in the event of an abnormal change in operating pressure. All wellheads shall contain an emergency shut off valve to the well distribution line. Lightning protection equipment shall be installed as required at every site in accordance with the National Fire Protection Association Standard 780. Tank battery facilities shall be equipped with a remote foam line and a lightning arrestor system.
- (n) Gas emission or burning restricted. No person shall allow, cause or permit Gas to be vented into the atmosphere or to be burned by open flame except as provided by law or as permitted by the Commission.

- (o) Grass, weeds, trash. Each Drill Site and Operation Site shall be kept clear of high grass, weeds, and combustible trash.
- (p) Lights. No person shall permit any lights located on any Drill Site or Operation Site to be directed in such a manner so that they shine directly on Streets or Buildings. To the extent practicable, and taking into account safety considerations, Drill Site and Operation Site lighting shall be directed downward and shielded so as to both prevent direct illumination of and minimize glare on Streets and Buildings within six hundred feet (600').
- (q) Muffling exhaust. Exhaust from any internal combustion engine, stationary or mounted on wheels, used in connection with the Drilling or for use on any production equipment shall not be discharged into the open air unless it is equipped with an exhaust muffler, or mufflers or an exhaust muffler box constructed of noncombustible materials sufficient to suppress noise and prevent the escape of noxious gases, fumes or ignited carbon or soot. All Fracturing operations shall be conducted during daylight hours unless the Operator has notified the Building Official that Fracturing will occur before or after daylight hours, and the Building Official has approved of such procedures.
- (r) Organic solvents. Organic solvents, such as trichloroethylene and carbon tetrachloride, shall not be used for cleaning any element, structure, or component of the Derrick, drilling rig, platform, and/or associated equipment, tools, or pipes. To the maximum extent practicable, high flash point mineral spirits shall be used.
- (s) Pipe dope for thread protection. Lead-free pipe dope shall be substituted for API specified pipe dope.
- (t) Pits. All Drilling and Wells drilled shall utilize a Closed Loop System. Fresh Water Fracing Pits must be netted at all times to exclude access by waterfowl.
- (u) Private roads and Drill Sites. Prior to the commencement of any Drilling, all roads used for access to the Drill Site and the Operation Site itself shall be at least twenty-two feet (22') wide, have an overhead clearance of fourteen feet (14') and shall be an All-Weather Hard Surface and maintained in accordance with the Fire Code, and to be non-erodible. In particular cases these requirements governing surfacing of roads may be altered at the discretion of the Fire Chief after consideration of all circumstances including, but not limited to, the following: distances from Streets and Buildings; topographical features; nature of the soil; and exposure to wind. All access roads must be kept clean and unobstructed at all times.

- (v) Signs (Refer to Part 2 for sign permitting requirements).
- (1) A sign shall be immediately and prominently displayed at the gate on the temporary and permanent site fencing erected pursuant to this Resolution. Such sign shall be of durable material, maintained in good condition and, unless otherwise required by the Commission, shall have a surface area of not less than sixteen (16) square feet with contrasting lettering not less than four inches (4") tall and shall be lettered with the following:
    - a. Location Name and Pad Name;
    - b. Name of Operator;
    - c. The emergency 911 number; and
    - d. 24 Hour telephone numbers of two (2) persons responsible for the Well who may be contacted in case of emergency.
  - (2) Permanent weatherproof signs reading "DANGER NO SMOKING ALLOWED" in both English and Spanish shall be posted immediately upon Completion at the Operation Site fencing at the entrance of each Operation Site and tank battery or in any other location approved or designated by the Fire Department. Sign lettering shall be four inches (4") in height and shall be red on a white background or white on a red background. Well and lease designation signage shall be posted in those locations and sizes as required by the Commission in Rule 3.3 Identification of Properties, Wells, and Tanks.
- (w) Storage of equipment. On-site storage is prohibited on the Operation Site. No equipment shall be stored on the Drill Site or Operation Site, unless it is necessary to the everyday operation of the Well. Lumber, pipes, tubing and casing shall not be left on the Operation Site except when Drilling or Well servicing operations are being conducted on the Operation Site. No vehicle or item of machinery shall be parked or stored on any Street, or upon any Operation Site which constitutes a fire hazard or an obstruction to or interference with fighting or controlling fires except that equipment which is necessary for Drilling or production operations on the Drill Site or Operation Site. The Fire Department shall determine whether equipment constitutes a fire hazard.
- (x) Storage tanks. All tanks intended to contain hydrocarbons and permanent structures shall conform to the API specifications unless other or additional specifications are approved by the Fire Department. All tanks shall require a Fire Code permit and application must be made in accordance with the Fire Code. All storage tanks shall be equipped with a secondary containment system including lining with an impervious material. The secondary

containment system shall be a minimum of one and one-half (1-1/2) times the contents of the largest tank in accordance with the Fire Code. Drip pots shall be provided at the pump out connection to contain the liquids from the storage tank. All tanks shall be set back pursuant to the standards of the Commission and the Fire Code. Each storage tank system shall be equipped with a level control device that will automatically activate a valve to close the Well in the event of excess liquid accumulation in the tank. No meters, storage tanks, separation facilities, or other above ground facilities, other than the wellhead and flow lines, shall be placed in a floodway identified by FEMA on the most current FIRM. Meters, storage tanks, separation facilities, or other above ground facilities proposed in the floodplain shall be outside of the floodway and shall be subject to approval by the Building Official.

- (y) Swabbing, bailing and purging Wells. No person shall begin the operation of swabbing a Well without first complying with the provisions of this Section. In swabbing, bailing or purging a Well, all deleterious substances removed from the borehole shall be placed in appropriate tanks and no substances shall be permitted to pollute any surface or subsurface fresh water. No Well shall be swabbed before a device, commonly known as a lubricator, has been placed on the flow casing above all outlets or flow lines of the Well. The lubricator shall be not less in diameter than the flow casing and equipped with an adequate oil saver or stuffing box at the top. The total inside length of the lubricator shall be not less than five feet (5') more than the total length of swab and turn back on swab line. The lubricator shall have a nipple not less than two inches (2") in diameter nor more than four inches (4") in length, placed not more than six inches (6") from the top of the flow line or lines between the gate valve on the flow lines and flow casings. The nipple shall be provided with a gate valve not less than two inches (2") in size. All equipment and parts of the lubricator shall be of a type designed and tested to withstand a pressure of 3,000 pounds per square inch. All pressure tests shall be by the hydrostatic method.
- (z) No refinery, processing, treating or absorption plant of any kind, shall be constructed, established or maintained within the Airport except as necessary to render gas into a quality suitable for delivery to third party pipelines. Natural gas fractionation will require a separate permit.
- (aa) Surface casing. Surface casing shall be in full compliance with the applicable rules and regulations of the Commission. Surface casing shall have a centralizer in the middle of the shoe joint, a centralizer on the top of the second joint of casing, and centralizers every fourth joint. Surface casing must be new pipe of API grade J or K or higher grade and have a minimum burst pressure rating of 2,900 psi. In the event a rupture, break or opening occurs in the surface or production casing, the Operator or drilling contractor shall promptly report the incident to the Building Official. Immediate action shall be taken to repair such casing and the Building Official shall be given the opportunity to witness the repairs.

- (bb) Valves. Each Well must have a shutoff valve to terminate the Well's production. The Fire Department shall have access to the Well site to enable it to close the shut-off valve in an emergency.
- (cc) Storage. Any permanent, temporary or portable tank, vessel, container, pit or impoundment used for storage of products, materials or wastes shall be selected and maintained to be fit for the purpose and capacity in which it will be used. Any such storage shall only be used for materials and wastes from oil and gas exploration and production activities within the boundaries of Dallas/Fort Worth Airport. All waste shall be disposed of in such time, place and manner as to comply with the air and water pollution control regulations of the Federal Government, the State, this Resolution and any other applicable requirement of the Airport Board.
- (dd) Watchperson. The Operator must keep a watchman or security personnel on site during the Drilling or re-working of a Well when other workers are not on the premises.
- (ee) Installation of pipelines on, under or across Airport property. The Operator shall apply to the Airport Board for a Permit to use the Airport for the purpose of constructing, laying, maintaining, operating, repairing, replacing and removing pipelines. Prior to installation, the owner of the pipeline shall submit to the Building Official the pipeline design criteria, including but not limited to, operating pressures, pipeline gradient and elevation to sea level, location, pipe ASTM grade, and pipe wall thickness. Prior to and subsequent to installation of each segment of new or replacement pipeline, the pipe and pipeline must receive and pass on-site inspection of compliance with the design criteria and the process of installation. All new or replacement pipe or pipelines shall be covered and must be at least 48 inches below the existing ground level as verified and approved by the Building Official. Operator shall:
- (1) Not interfere with or damage existing water, sewer or gas lines or the facilities of public utilities located on, under or across a Street.
  - (2) Furnish to the Building Official a site plan showing the location of such pipelines.
  - (3) Design, construct, maintain and operate natural gas pipelines in accordance with 49 U.S.C. 60101, et seq.; 49 Code of Federal Regulations (CFR) Part 191, Transportation of Natural and Other Gas by Pipeline; Annual Reports, Incident Reports, and Safety-Related Condition Reports; 49 CFR Part 192, Transportation of Natural and Other Gas by Pipeline: Minimum Federal Safety Standards; and 49 CFR Part 193, Liquefied Natural Gas Facilities: Federal Safety Standards.

- (4) Grade, level and restore such property to the same surface condition, as nearly as practicable, as existed prior to the laying of the pipeline.
  - (5) If a pipeline becomes unsafe or is not properly maintained, or in the event a leak is detected, the Operator of the line shall immediately evaluate the leak or release and either shut in the pipeline or, as soon as possible, shall initiate repairs according to the procedure in section (oo) below.
  - (6) As mandated by DOT requirements under CFR 192.701, each owner or operator of a gas pipeline for which a Permit is required under this Resolution shall have it surveyed at least twice each year with intervals not to exceed 7.5 months for the purpose of determining whether it is in safe condition and free from leaks, breaks or open spaces. The owner or operator shall provide a copy of the leakage survey report required under DOT CFR 192.706 supported by an affidavit by the person making the survey to the DFW Department of Public Safety Fire Prevention Office, within 30 days of completion of the survey. For failure to timely make the survey and report, or if the report discloses or it otherwise appears that any line is leaking, defective or unsafe, the pipeline shall be closed and shut-in until such time as the leak has been repaired, or a repair plan or report has been approved by the Building Official.
  - (7) The location of all new or replacement pipe or pipelines shall be marked by the owner(s) thereof or by the person installing or operating the pipe or pipeline. Marker signs shall be placed at all locations where pipe or pipelines cross property boundary lines and at each side of a Street which the pipe or pipeline crosses. The top of all marker signs shall be a minimum of four feet (4') above ground level, and the support post must be sufficient to support the marker sign and shall be painted yellow or such other color as may be approved by the Building Official. All marker signs shall comply with US Department of Transportation standards regarding size, shape, color, installation, positioning, maintenance and other related signage requirements. It is the joint and severable responsibility of the owner and the operator of any and all pipelines to maintain the markers in accordance with this Section.
- (ff) Streets. No Permit shall be issued for any Well to be drilled within any Street, and no Street shall be blocked, encumbered, or closed due to any Exploration, Drilling or production operations.
- (gg) Vehicle routes. Vehicles associated with Drilling and/or production in excess of three (3) tons shall be restricted to those arterials or routes designated by the Airport.
- (hh) Tank specifications for a Gas Well. All tanks and permanent structures shall conform to the API specifications unless other specifications are approved by

the Airport Board. The top of the tanks shall be no higher than twelve feet (12') above the terrain surrounding the tanks.

- (ii) All Drilling, re-entry and operations at any Well shall be conducted using the best available technology. All casing, valves, Blowout Preventers, drilling fluids, tubing, bradenhead, Christmas tree and wellhead connections shall be of a type and quality consistent with sound engineering practices. The setting and cementing of casing and running of drill stem tests shall be performed in a manner consistent with the best available technology. All persons engaged in Drilling or production operations shall observe and follow the recommendations and regulations of the API and the Commission, except in those instances specifically addressed by this Resolution.
- (jj) Upon Completion of the Well, the Operator shall provide a copy of the Commission Completion Report W15, and certify by affidavit that the Well has been completed according to good engineering practices. The affidavit shall stipulate the number of sacks of cement, the class of cement, blended materials, weight of cement in pounds per gallon, cement displacement pressure, final pumping pressure and whether checkvalves held the pressure. Commencement and completion times of such operation shall be stipulated. The affidavit must be completed by a cementing service company and signed by both the Operator and the cementing service company.
- (kk) No person shall commence any operation to change the equipment of a Well for the purpose of cleaning, repairing or reconditioning any such Well, before notifying the Building Official that such operation is to be commenced. No person shall commence such operation unless he receives approval. The Building Official shall give approval for converting from natural to artificial production if it appears that the provisions of this Resolution have been and are being complied with.
- (ll) In no case shall Gas or air be transported through any pipeline at a working pressure in excess of 1,000 pounds. If it is necessary to use greater working pressure, a gas or air booster plant shall be installed not closer than 75 feet from the Derrick floor of a Well or tank battery and the compressor unit not less than 100 feet from the Derrick floor of the Well being served. In no event shall more than 1,500 pounds working pressure be used in flowing a Well by artificial means.
- (mm) All Gas gathering lines and pipelines on DFW Airport shall be designed, installed, tested and maintained in accordance with the most current version of 49CFR192 – Transportation of Natural or Other Gas by Pipeline: Minimum Federal Safety Standards. All permanent fresh water and Brackish water HDPE lines shall be tested to ASTM D-2837 following installation or repair.
- (nn) At each Well where air or gas lift is used, there shall be placed on the air or gas lift an indicating pressure gauge which shall show the working pressure of air or

gas delivered to the Well at all times. All gauges installed on lines shall be tested and corrected every six (6) months.

- (oo) The Building Official shall inspect all pressure lines in use at any Well or at any project to ensure that tubing, fittings, equipment or connections are reasonably tight, safe and free from leaks. If it becomes necessary to change or remove any pipeline, the entire expense of change or removal shall be borne by the owner of the line requiring repair. Each leak noted shall be classified by a qualified person as to its risk to people and property based on the leak location, line use and content, line pressure, surrounding land use and other considerations. Each leak shall be classified upon discovery, and a repair schedule shall be developed to make repairs as soon as possible, but not to exceed one month. The leak shall be monitored regularly until repairs are made. All such repair plans shall be submitted to and approved by the Building Official.
- (pp) All pipelines, connections and fixtures installed or used for the purpose of gas transportation shall be operated and maintained in a safe manner at all times so as to prevent all leakage or escape of their contents.
- (qq) The Building Official shall have the authority to require the immediate shutting in or closing of any Well if he finds there exists, within a 100-foot radius of any Well, any Gas or gasoline vapor in a quantity sufficient to constitute, in his sole judgment, or in the sole judgment of the Fire Chief, a fire hazard. The Well shall remain shut in or closed in until the hazard and its cause have been remedied.
- (rr) In the event of a fire or discovery of a fire, smoke, or unauthorized release of flammable or hazardous materials , the Operator shall immediately report such condition to the Fire Department.
- (ss) Every Disposal Well shall be constructed so as to seal the injection zone from the upper portion of the casing. Cement shall be circulated to the surface for injection zone casing. The annulus between the casings shall be filled with a non-corrosive fluid, then sealed and a 1/4-inch female fitting with cutoff valve shall be attached so that the pressure annulus may be measured by the Building Official by attaching a gauge with a 1/4-inch male fitting. The annulus between the production casing and the injection tubing shall be pressure tested to a pressure at least 250 psi greater than the injection pressure proposed for the Well. The Building Official shall be given the opportunity to witness and approve the pressure testing. A copy of all H-5 test reports must be provided to the Building Official. A pressure shall be maintained in the annulus sufficient to monitor the fluids in the annulus. Any significant deviation from the established pressure shall be cause to shut down the Well, and may result in cancellation of the operating Permit, until the established pressure can once again be maintained.

- (1) The DFW Airport Permit for a Disposal Well shall reflect the maximum injection pressure as permitted by the Commission. Exceeding this injection pressure shall be considered a violation of this Section.
- (2) Injection lines for such wells shall be buried to a minimum depth of four feet (4'), and shall be pressure tested (static) annually at a minimum of 150 percent of the pressure normally encountered at the injection pump discharge for a period of hours to be fixed by the Building Official. The Building Official shall be notified in writing five (5) days in advance of such test and may supervise it. Test results shall be filed with the Building Official upon completion.
- (3) Before performing any down-hole work on a Disposal Well, the Operator shall notify the Building Official at least five (5) days in advance of performing the work, or as soon as practical in the event of emergency repair work. The Building Official shall be given the opportunity to witness the installation of tubing and packer in the Disposal Well. The annulus between the injection tubing and the production casing shall then be pressure tested as required by Commission Rule 3.9.12 Testing. The Building Official shall be given the opportunity to witness the pressure testing of this annulus.
- (4) The Operator of the well shall submit to the Building Official all reports and notifications at the same frequency that such reports and notifications are required under TX RRC Rule 3.9 Disposal Wells, or its equivalent.

## **SECTION 15 SCREENING**

- (a) Throughout the entire Exploration, Drilling, and production process there shall be screening improvements (fences, walls, Berms and landscaping) required during each phase of the process if the Drill Site or Operation Site is visible from a Building or Street, exclusive of construction roads, haul roads or access roads. Without regard to visibility, each Fresh Water Fracing Pit that is open to the atmosphere or surface shall be screened.
  - (1) During Drilling. A temporary chain link fence with all-weather screening fabric at least six feet (6') in height shall be established around the entire Operation Site to obscure view of the Drilling activities. A secured entrance gate shall be required. All gates are to be kept locked when the Operator or his employees are not within the enclosure. A "Knox Padlock" or "Knox Box with a key" shall be provided to access the Well site to be used only in case of an emergency.
  - (2) Completion through Abandonment (production phase). A painted architectural metal fence or other approved fencing and/or screening shall

be required to enclose and visually screen the Well and all associated equipment. An earthen Berm may also be required. The masonry walls, Berms, and landscaping shall be in compliance with standard engineering and design practices and shall meet the following minimum requirements:

- a. The painted architectural fence or other approved fencing and/or screening material and design shall be generally compatible with the design of similar facilities, Building and structures on and/or adjacent to the site as approved by the Building Official; and
  - b. Painted architectural fences shall be at least eight feet (8') in height.
- (3) Each Fresh Water Fracing Pit shall be surrounded by a temporary chain link fence with all-weather screening fabric at least six feet (6') in height. A secured entrance gate shall be required. All gates are to be kept locked when the Operator or his employees are not within the enclosure. A "Knox Padlock" or "Knox Box with a key" shall be provided to access the Well site to be used only in case of an emergency. If the Fresh Water Fracing Pit is open to the atmosphere or the surface, it shall be covered by netting sufficient to inhibit access to the pit by fowl.
- (b) Gate specifications. All temporary fences and masonry walls shall be equipped with at least one (1) gate. The gate shall meet the following specifications:
- (1) At least one gate shall be not less than twelve feet (12') wide and be composed of two (2) gates, each of which is not less than six feet (6') wide, or one (1) sliding gate not less than twelve feet (12') wide. If two (2) gates are used, gates shall latch and lock in the center of the span;
  - (2) The gates shall be of chain link construction, with all-weather screening fabric, that meets the applicable specifications, or of other approved material that, for safety reasons, shall be at least as secure as a chain link fence;
  - (3) The gates shall be provided with a combination catch and locking attachment device for a padlock, and shall be kept locked except when being used for access to the site; and
  - (4) Operator must provide the Fire Department with a "Knox Padlock" or "Knox Box with a key" to access the Well site to be used only in case of an emergency.

**SECTION 16**  
**CLEANUP AND MAINTENANCE**

- (a) Cleanup after well servicing. After the Well has been completed or there has been an Abandonment, the Operator shall clean the Drill Site or Operation Site, complete restoration activities and repair all damage to property caused by such operations within sixty (60) days.
- (b) Clean-up after spills, leaks and malfunctions. After any spill, leak or malfunction, the Operator shall remove or cause to be removed to the satisfaction of the Fire Department and the Building Official all waste materials from any property affected by such spill, leak or malfunction. Clean-up operations must begin immediately. If the Operator fails to begin clean-up within twenty-four (24) hours, the Airport Board shall have the right to contact the Commission in order to facilitate the removal of all waste materials from the property affected by such spill, leak or malfunction.
- (c) Painting. All production equipment shall be painted and maintained at all times, including wellheads, pumping units, tanks, and Buildings. When requiring painting of such facilities, the Building Official shall consider the deterioration of the quality of the material of which such facility or structure is constructed, the degree of rust, and its appearance. Paint shall be non-reflective and of a neutral color, compatible with surrounding uses. Neutral colors shall include sand, gray and unobtrusive shades of green, blue and brown, or other neutral colors approved by the Building Official.
- (d) Blowouts. In the event of the loss of control of any Well, Operator shall immediately take all reasonable steps to regain control regardless of any other provision of this Resolution and shall notify the Building Official and Fire Chief as soon as practicable. If in the opinion of the Building Official or the Fire Chief, a danger to persons and/or property exists because of such loss of Well control and that the Operator is not taking or is unable to take all reasonable and necessary steps to regain control of such Well, the Building Official may then employ any well control expert or experts or other contractors or suppliers of special services, or may incur any other expenses for labor and material which the Building Official deems necessary to regain control of such Well. The Airport Board shall then have a valid lien against the interest in the Well of all working interest owners to secure payment of any expenditure made by the Airport Board pursuant to such action of the Building Official in gaining control of said Well.

**SECTION 17**  
**PLUGGED AND ABANDONED WELLS**

- (a) Surface requirements for the Abandonment of a Well. Whenever Abandonment occurs pursuant to the requirements of the Commission, the Operator shall be

responsible for the restoration of the Well site to its original condition as nearly as practicable, in conformity with the regulation of this Resolution.

(b) Abandonment shall be approved by the Building Official after restoration of the Drill Site and/or Operation Site has been accomplished in conformity with the following requirements at the discretion of the Building Official:

(1) The Derrick and all appurtenant equipment thereto shall be removed from the site;

(2) All tanks, towers, and other surface installations shall be removed from the site;

(3) All concrete foundations, piping, wood, guy anchors and other foreign materials regardless of depth, except surface casing, shall be removed from the site, unless otherwise directed by the Commission;

(4) If any soil was contaminated, it shall be removed in accordance with local, State and Federal regulations;

(5) All holes and depressions shall be filled to grade with clean, compactable soil;

(6) All waste, refuse or waste material shall be removed; and

(7) During Abandonment, Operator shall comply with all applicable sections in this Resolution.

(c) Abandoned Well requirement. The Operator shall furnish the following to the Building Official:

(1) A copy of the approval of the Commission confirming compliance with all Abandonment proceedings under state law; and

(2) A notice of intention to abandon under the provisions of this Section and stating the date such work will be commenced. Abandonment may then be commenced on or subsequent to the date so stated.

(d) Abandonment requirements prior to new construction. A Well Site or Drill Site where there has been an Abandonment shall meet the most current Abandonment requirements of the Commission prior to the issuance of any Permit for development of the property. No structure shall be built over an abandoned Well.

(e) The Operator can only abandon a Well if the Building Official has reviewed and approved the Abandonment.

## **SECTION 18 TECHNICAL ADVISOR**

The Airport Board may from time to time employ a technical advisor or advisors who are experienced and educated in the gas industry or the law as it pertains to gas matters. The function of such advisor(s) shall be to advise, counsel or represent the Airport Board on such matters relating to gas operations within the Airport as the Airport Board may want or require and the effect thereof, both present and future, on the health, welfare, comfort and safety of the public. In the event such technical advisor(s) is (are) employed for the purpose of advising, counseling or representing the Airport Board relative to an Operator's unique and particular set of circumstances, case or request relating to this Resolution, then the cost for such services of such technical advisor(s) shall be assessed against and paid for by such Operator in addition to any fees or charges assessed pursuant to this Resolution. Prior to the employment of a technical advisor, the Airport Board shall inform the Operator of the intended scope of work and the estimated costs and expenses.

## **SECTION 19 MEANS OF APPEAL**

Refer to Part One, Construction and Fire Prevention Standards Resolution for Board of Appeals.

## **SECTION 20 VARIANCE RESOLUTION COMMITTEE**

The Airport Board hereby establishes a Variance Resolution Committee for Gas Exploration and Production, hereinafter referred to as the Variance Resolution Committee, for the purpose of considering variances to the requirements of Part Nine. The Variance Resolution Committee shall consist of the following Airport staff positions:

- Vice President, Commercial Development or successor department
- Vice President, Department of Public Safety or successor department
- Vice President, Finance or successor department
- Vice President, Operations or successor department
- Vice President, Planning or successor department

(a) An Applicant for a Permit required by this Part may apply for a variance from the requirements of this Part by submitting to the Building Official a written request for variance. The request must include the following:

- (1) Description of the requested variance and an explanation of why it should be granted;

- (2) Description of alternatives considered and why each is not the preferred alternative;
  - (3) Description of the economic consequences if the variance is not granted; and
  - (4) Description of how the level of health, safety and welfare of the public will be maintained if the variance is granted.
- (b) The Building Official shall forward copies of the variance request to the Variance Resolution Committee members. On a case-by-case basis, the Variance Resolution Committee shall consider the following in granting a variance:
- (1) Whether the operations proposed are safe and reasonable under the circumstances and conditions prevailing in the area, considering the particular location and the character of the improvements located there;
  - (2) How the operations proposed compare to available alternatives;
  - (3) Whether the operations proposed would conflict with the orderly growth and development of the Airport;
  - (4) The economic consequence if the variance is not granted;
  - (5) Whether the operations proposed adequately protect the health, safety and welfare of the public; and
  - (6) Whether the operations proposed provide acceptable access for fire personnel and fire fighting equipment.
- (c) Approval of a variance requires that a minimum of three Variance Resolution Committee members vote in favor of the approval. The Variance Resolution Committee shall notify the Airport tenants affected by any request for variance and allow them to address the request in writing within twenty (20) days of the notice. Only variances that would result in a setback distance between any Well or Disposal Well and a Building to less than the minimum setback outlined in Section 13 of this Part will be deemed to affect an Airport tenant.

The Variance Resolution Committee shall not be required to hold public hearings, except upon request of two Committee members. The Variance Resolution Committee shall notify the Airport Board in writing of each variance request at least twenty (20) days prior to the granting of such variance. Upon request of two voting Airport Board members, a variance shall be placed on a public meeting agenda of the Airport Board. The Variance Resolution Committee shall not thereafter grant the variance request without consent of the Airport Board.

The details of each action granting or denying the requested variance shall be recorded and entered in the files of the Office of the Building Official, and the Building Official shall forward a letter to the Applicant stating whether the Variance Resolution Committee has approved or denied the variance request and listing any conditions placed upon an approval. The Variance Resolution Committee shall report each such action to the Airport Board on at least a quarterly basis.

## **SECTION 21 SEVERABILITY CLAUSE**

It is the intention of the Airport that the phrases, clauses, sentences, paragraphs and sections of this Resolution are severable, and if any phrase, clause, sentence, paragraph or section of this Resolution shall be declared unconstitutional or unenforceable by the valid judgment or decree of any court of competent jurisdiction, such unconstitutionality or unenforceability shall not affect any of the remaining phrases, clauses, sentences, paragraphs and sections of this Resolution.